

BUREAU
VERITAS

INSPECTION REPORT

NO. R114191223.01

Page: 1/3

☐ Interim
☒ Final

BV Job nr: KHO.INI.19.206.SA

PROJECT: Third Party Inspection for GENERATOR

Ref: KHO.IVS.2018-53

BV Client: SUDHIR

P/o nr: N/A
(client to BV)

Manufacturer: PRECISION INDUSTRIES

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	QTY
VISUAL EXAMINATION AND FUNCTIONAL TEST OF GENERATOR.	SG-378-300 / F19P1504338	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No			
Title	Reference n°	Rev.	Approved by
EQUIPMENT DATA SHEET	..	-	-

INSPECTIONS :

Inspection place & Date or Period:SUDHIR,
HARADH Dec 23, 2019Stage of inspection :

- ☐ Before manufacturing
☐ During manufacturing
☒ Final
☐ Packing

Type of inspection:

- ☐ Pre-inspection meeting
☐ Document and QC record review
☒ Visual examination, checks
☐ Witnessing tests
☐ Manufacturing progress status
☐ Vendor assessment
☒ Final inspection
☐ Packing

(for details see continuation sheet)

Stamping :☒ NoResults of inspection : ☒ Satisfactory ☐ UnsatisfactoryNon Conformities Reports (NCR):

o NCR's issued during reported period : N/A

o List of outstanding NCR's : N/A

Main Conclusions & Remarks: (for details see continuation sheet)

Third party visual inspection of 1 unit of GENERATOR was carried out and found satisfactory at the time of Inspection.

Valid Sticker Number : LFT-S-01-15511

Next visit scheduled: June 22 , 2020

BUREAU
VERITAS**INSPECTION REPORT**
NO. R114191223.01☐ Interim
☒ Final

BV Job nr: KHO.INI.19.206.SA

Description of the inspections carried out:**1. Introduction:**

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the General condition which Regulate the intervention of the society IVS-Lifting/B&F Department at the Request of SUDHIR Company on the purpose of Third Party Inspection of One GENERATOR with Model number: P1313C and S/N : F19P1504338 .

2. Attendees :

SUDHIR

3. Scope of Inspection :

a. Visual Inspection & Functional Test of GENERATOR

1- General Data	
Equipment Type	GENERATOR
Manufacturer	PRECISION INDUSTRIES
Model	P1313C
Serial Number :	F19P1504338



BUREAU
VERITAS

INSPECTION REPORT

NO. R114191223.01

☐ Interim
☒ Final

BV Job nr: KHO.INI.19.206.SA

3- Inspection and Test Results

Acceptance criteria	Result	Remarks
1. Document review (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of Unit-leaks, wear, damage, loose connection/components, corrosion.	Pass	Found good condition.
3. Check engine oil level (check for proper oil level and oil operating pressure.	Pass	Found good condition.
4. Check air filter	Pass	Found good condition.
5. Electrical, (conduct general inspection of wiring and connection cable termination, corrosion, damage	Pass	Found good condition.
6. Prime mover / Generator (Check for debris, foreign objects, looser broken fittings; check guards and components; look for any unusual condition of vibration, leakage, noise, temperature or deterioration.	Pass	Found good condition.
7. Check engine drive belts, fan coupling device-tension wear, whether cracking, damage.	Pass	Found good condition.
8. Check emergency switches.	Pass	Found good condition.

➤ **Conclusion:**
 The GENERATOR found in good condition at the time of Inspection.

Inspected by:

ALI ALHOMOU
 IVS- Inspector



Checked by:

IVS- Inspection Team Leader

Date of issue: 24 Dec 2019

Inspection centre: BUREAU VERITAS ALKHOBAR