



Precision Industries
Testing Department

GENERATING-SET
LOAD TEST

Model No: PI 313 C 60 Hz
Type: Close Job No: 10107
Color: White Date: 02/07/2019

Serial Number:								
PI Model No:	PI 313 C	Prime Power:	284	[kVA]	P.F (Load):	1	Voltage:	220

Generating Set Details:

Engine:	Cummins	Model No: QSL9 - G3	Serial No: 84511840
Alternator:	Stamford	Model No: UCDI 274K1	Serial No: N17E207899
Controller:	DSE	Model No: 6120	Serial No: 7169653
C. Breaker:	Metasol	Model No: ABN 803 C	Serial No: N/A
C.Transformer:	VTEKE 1000/5A	Model No: N/A	Serial No: N/A
AVR:	Stamford	Model No: SX 460	Serial No: 111505 - 2661
Cooling System:	Water cool	Enclosure Type: Canopy	Protection Class: IP23

Load Test Ambient Conditions:

Temperature	45	[°C]	Altitude:	0	[m]	Humidity:	39	%
-------------	----	------	-----------	---	-----	-----------	----	---

Generating Set Rating:

Testing Full Load Current:	596.25	Amps	Nominal Current:	745.3	Amps
Power Correction Factor (De-rating):	0.00	%	Corrected Prime Power:	0.0	[kVA]

LOAD TEST

Load	Run Time	Freq	Speed	VOLTAGE L-L			CURRENT			Power	Coolant Temp	Oil Pressure	Charg-Alt.
				L1	L2	L3	L1	L2	L3				
%	min	Hz	RPM	V	V	V	A	A	A	kW	C	bar	VDC
0 %	5	60	1800	220	220	220	-	-	-	-	70	5.28	28.5
25 %	5	60	1800	220	220	220	149	148	148	56.0	76	5.08	28.5
50 %	5	60	1800	220	220	220	300	300	300	114.0	80	4.80	28.5
75 %	5	60	1800	220	220	220	452	450	450	173.0	85	4.55	28.5
100 %	10	60	1800	220	220	220	598	598	598	229.0	90	4.24	28.5
110 %	10	60	1800	221	221	221	652	652	650	250.0	93	4.16	28.5

LOAD ACCEPTANCE TEST

Suddenly Block Load %	Voltage [V]	Frequency [Hz]	Current [A]	Response Time [sec]
50%	220	60.0	300	0
0%	224 - 220	61.5 - 60.0	0	2
50%	217 - 220	58.6 - 60.0	303	2

PROTECTION SYSTEM TEST

Over Frequency Warning / SD	Under Frequency Warning / SD	Over Voltage Warning / SD	Under Voltage Warning / SD	Oil Pressure Warning/SD	Coolant Level SD	Coolant Temp Warning/SD
65 / 67	55 / 53	240 / 260	180 / 160	1.0	ECM OK	100 / 105 °C

ACCESSORIES DETAILS

Model:		Serial No.	
Model:		Serial No.	

TESTED
Testing Department

PI Document no. PI-TST-LT-01 Rev. 00