

THIRD PARTY INSPECTION CERTIFICATE
GENERATOR

Certificate No : HIT-CRT-22-1155

Job No JO-INS-22-591

Sticker No	1273
Result	Pass

Timesheet	CL-1245
Checklist	CL-1245

Client Name & Address	Inspection Date	15-Mar-2022
Sudhir Equipment Rental Company	Expiration Date	14-Mar-2023
Jeddah	Validity	12 Month's
Kingdom of Saudi Arabia	Types of Inspection	
Equipment Location	Jeddah	Periodic Visual & Functional

Equipment Description	Load Test Chart
Diesel Driven Generator	Boom ↔ Radius → Test Load S.W.L.
Engine by PERKINS	(Meter) (Meter) (Tonne) (Tonne)
	NA NA NA NA

Load Limit (S.W.L.)	650 kVA
Serial No.	VEPL/2019-20/0021
Model	VEPL/2019-20/0021
Frequency	60 Hz
Voltage	400 V
Rated Current	520 A
Rotating Speed	1800 rpm
Wheel Type	NA

Manufacturer	VARADA ENERGIES
Date of Mfg.	2019
Owner ID/Plate No	SG-400-650
Max Platform Height	NA
Max Length	NA
Max Width	NA
Gross Weight	9800 kg
Person Allowed	NA

Previous Inspection Details	Next Inspection Date	Reference Standard
NA	15-Mar-23	IEC 88528-11

Recommendation

Found satisfactory at the time of Inspection.

Authorized By: ASHADULLAH KHAN

Inspected By: KALEEM SHARIEF

Kaleem Sharief

Signature & Stamp

No liabilities will be considered against Haykalah Inspection Est. for failure, damage or other occurrence to client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. The concerned inspector or representative has thoroughly examined the equipment in accordance to the relevant standards. Inspection indicates that the mentioned equipment/tools/machine has no apparent defects which may prove dangerous during normal operation and it's found satisfactory for further use with provided their regular maintenance and operated by a certified operator. This certificate/report shall not be generated without an official approval in between Haykalah Inspection Est. and Client. Certificate becomes invalid if any modification/repair is made to the equipment.