

CERTIFICATE OF THOROUGH EXAMINATION OF ELECTRIC POWER EQUIPMENTS (REVISION 2)

Date of thorough examination : 08-05-2025		Date of issue : 08-05-2025		Report No. : ESICO-LFT-R25-2481	
Name & Address of employer		Location		Sticker No	Standards
Sudhir Equipment Rental Company		P3 Seven Al-khobar		4123	IEC ISO NFPA 110/ ISO- 8528
Equipment Identification No	Equipment Description	Safe Working Load(s)	Date of Manufacture	Manufacturer Name	
A20P1505206 OR SG-421-250	Diesel Powered Generator Electric DG Set Rating(Prime Power): 160kva- 3 phase Set performance Class: H. Rated Power factor: 0.8 Max. site altitude above sea-level: 1000m Max. site ambient temperature: 50 deg.C. Rating Frequency: 60Hz. Rating voltage: 400v. Rating: 128kw	Mass: 2570kg	February, 2024	Varada Energies PVT. Ltd.	
Is this the first examination after installaton or assembly at a new site or location?		Was the examination carried out within an interval of?		- 6 Months	
Yes - No ☒		Yes ☒ No -			
If the answer to the above question is YES, has the equipment been installed correctly?		In accordance with an examination scheme?		Yes ☒ No -	
Yes - No -		After the occurence of exceptional circumstances?		Yes - No ☒	
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE					
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?					No
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)				Yes by : No	
Particulars of any repair, renewal or alteration required to remedy the defect identified above : No					
Particulars of any tests carried out as part of the examination (if none state NONE) : NONE					
Observation/additional comments relative to this thorough examination : VISUAL INSPECTION AND FUNCTION CHECKS WAS PERFORM AT THE TIME OF INSPECTION; EQUIPMENT WAS FIT FOR USE.					



For confirmation scan QR code
search with report number : **ESICO-LFT-R25-2481**

☒ Safe to operate

Next Inspection : 07-11-2025

Inspected by : Michael Arthur

