



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20246723

Customer : Sudhir Equipment Rental Company
Location : Dammam, Kingdom of Saudi Arabia.
Description : Generator
Make : VARADA ENERGIES PVT.LTD
Model Number : VEPL-400-CDP
Serial No : VEPL/2020-21/0002
ID. No. : SG-443-400
Capacity : 400 KVA

This is to certify that the Description detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the Specifications relevant here to.

Date of Inspection: 08-SEP-2024

Due Date: 08-SEP-2025

Additional Certification

Sticker Number: 202781

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤ +٩٦٦

هاتف ٠٥١٥ ١٣ ٣٦٧ +٩٦٦

Certificate No: UIC/DAM/20246723

Specification:

Rated Power in kva	:	400.0 Kva	-	Engine S/number	:	3008606644
Rated Power Factor	:	0.8	-	Rated Frequency	:	60 Hz
Rated Voltage	:	400	-	Phases	:	3 phases
Speed	:	1500 Rpm	-	Engine Make	:	Volvo penta
Current	:	556.5 A	-	Alternate Ser.Number	:	N20B051854
Year	:	2020				

Inspection and Test:

Internal Visual Test	:	Satisfactory	General Surface Test	:	Satisfactory
Emergency Shut-Down	:	Satisfactory			

Comments & Recommendations:

The **Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.

7. Remember - Safety always comes first!

Inspected By:

Industrial Inspector



Approved By:

QA/QC Engineer

No. 24725

Company Name & Address of the Site Location:

Company / Customer Name : Sachin

Purchase Order No. : _____

Mr. /Mrs: _____

Date Of Calibration / Inspection : 08 Sep. 2024

Mobile/Tel. No.: _____

Calibration / Inspection Validity : 6M / 1Y

Email ID : _____

Location : San Francisco

[illegible]

Cal. Engr/Insp. Sign: [Signature] Name: Wade Kraft

(Client Sign) _____ Name: _____ Contact No: _____ Site Location: _____

Witnessed & Approved by