

Certificate of Visual Examination

Client Name :		
Sudhir Equipment Rental Company		
Work/ Rig Location:	Certificate Number:	Issued Sticker No.(if Applicable)
SUDHIR DAMMAM YARD	ZM-20-Z085- 178	W.4345
Date of Last Inspection	Date of Inspection:	Date of Next Inspection:
NEW	10-Jan-2021	9-Jan-2022
Relevant Standards:	O.E.M / C.O.C / Reverse Engineering Cert. No.	Color Code (If Applicable for the item) (Current applicable Color at the Time of Inspection)
BS EN 60034-22:2009	478	
Zamil Ref No.	Customer Requisition No.	N/A
ZAM-0051-01-21	SG-EPO-2020-0148	

I.D. NUMBER	QTY	DESCRIPTION	SWL / CAPACITY
SG-478-650	01	DIESEL GENERATOR MANUFACTURER : VARDA MODEL: VEPL-650-CDP S/N: VEPL/2020-21/0040 RATED VOLT : 650 KvA RATED FREQUENCY : 60 Hz NOTE : Visual Inspection & Functional Test Were Carried Out On The Above Mentioned Equipment , At The Time Of Inspection No Any Abnormality Found.	650 KVA

Result: During the Time of Visual Inspection, Result found Satisfactory.

This Certificate by Company Under Its General Conditions of Services. This Issuance of This Certificate Does Not Exonerate the Buyers or Sellers from Exercising All Their Rights Discharging All Their Liabilities Under the Contacts of Sale. Stipulations to Contrary Are Not Binding on The Companies Responsibility Under This Certificates Is Limited to Proven Negligence and Will in No Case Be More Than Ten Times the Amount of The Free or Commission. Thr. Above Findings Are Limited to Date Place of Intervention Only. The Company Is Neither an Insurer Not a Guarantor Disclaims All Liabilities in Such Capabilities.

Inspected By:

Name : HASSAN ALGUDAIHI

Qualifications : LEEA & ASNT NDT Level II Certified

Signature & Stamp:



طريق الملك فهد - حي الضباب - الدمام - س.ت: 2050069798 - ص.ب 419 - الدمام 31411

King Fahad Road - Al-Dhabab Avenue - Dammam - C.R.: 2050069798 - P.O. Box 419 - Dammam 31411 Email: info@zamil.sa