



CERTIFICATE OF THOROUGH EXAMINATION

GENERATOR

CERTIFICATE / REPORT NO : CRT-172338

STICKER NO : 139823

JOB NO : WO-47767

EQUIPMENT OWNER : SUDHIR RENTALS		TYPE OF INSPECTION : INITIAL INSPECTION	
LOCATION: AL KHUSHYBI L&T	DATE OF INSPECTION : 02-Aug-2025	Frequency 6 month	Next Inspection Due 01-Feb-2026
EQUIPMENT DESCRIPTION : DIESEL ENGINE OPERATED GENERATOR WITH CAPACITY OF 500 KVA			
MANUFACTURER : VARADA ENERGIES PVT. LTD.	MODEL/TYPE : VEPL-500-CPD	MANUFACTURED YEAR : 2021	
SERIAL NO : CEPL/2020-21/0048	OWNER ID : SG-485-500	WORK PROCEDURE NO : SA-WP-06	
REFERENCE STANDARDS : ISO 8528-13:2016	DATE OF PREVIOUS INSPECTION : 06-May-2025	PREVIOUS INSPECTION DETAILS: TUV GULF 014710	

RATED POWER : 400 KW	RATED FREQUENCY ; 60 HZ
RATED CURRENT ; 500 KVA	RATED VOLTAGE : 400 V
RESULT : SATISFACTORY - PASS	CHECKLIST NO : 78927
REMARKS/RECOMMENDATION : AT THE TIME OF INSPECTION, THE ABOVE-MENTIONED EQUIPMENT WAS THOROUGHLY EXAMINED IN ACCORDANCE WITH THE APPROPRIATE STANDARD PROVISIONS. THE EQUIPMENT WAS FOUND TO BE FREE FROM APPARENT DEFECTS THAT COULD AFFECT SAFE OPERATIONS.	

Reviewed By : MOHAMED ANWAR DEEN

Authorised Inspector : MD. MUQSHAIID ALAM



SERIAL NO: CEPL/2020-21/0048 VALID TILL : 01-Feb-2026 Report No: CRT-172338 SERIAL NO: CEPL/2020-21/0048 VALID TILL : 01-Feb-2026 Report No: CRT-172338
Note: This inspection certificate confirms that the inspected equipment comply with the specified requirements as per the inspection criteria.
However, this document does not constitute a conformity certificate for SABER.

ملحوظة: تؤكد شهادة الفحص هذه أن المعدات التي تم فحصها تتوافق مع المتطلبات المحددة وفقاً لمعايير الفحص. مع ذلك، هذه الوثيقة لا تعتبر شهادة مطابقة لمنصة سابير.

THIS CERTIFICATE BECOMES INVALID, IF ANY ALTERATION/REPAIR OR MODIFICATION IS MADE TO THE EQUIPMENT

THE CONCERNED INSPECTOR OR REPRESENTATIVE HAS THOROUGHLY EXAMINED THE EQUIPMENT IN ACCORDANCE TO THE RELEVANT STANDARDS. EXAMINATION INDICATES THAT THE SAID EQUIPMENT HAS NO APPARENT DEFECTS OR DEFORMATION WHICH MAY PROVE DANGEROUS DURING NORMAL OPERATION. THE SAID EQUIPMENT IS FOUND TO BE SATISFACTORY FOR FURTHER USE, PROVIDED THERE IS REGULAR MAINTENANCE AND OPERATED BY A CERTIFIED OPERATOR. THIS CERTIFICATE IS GRANTED SUBJECT TO THE CONDITION THAT IS AGREED & UNDERSTOOD THAT STANDARD ARABIA INSPECTION CO. LTD.'S LIABILITY SHALL BE LIMITED TO THE ACTS OF ITS EMPLOYEES ON PREMISES OF SUBCONTRACTORS. UNDER NO CIRCUMSTANCES WHATSOEVER SHALL STANDARD ARABIA INSPECTION CO. LTD. BE LIABLE FOR ANY INJURY OR DAMAGE TO ANY PERSON OR OCCURRING AS A RESULT OF NEGLIGENCE OPERATION OR ANY DEFECT IN MATERIALS, MACHINERY, EQUIPMENT OR SYSTEMS OTHER THAN DEFECTS ASCERTAINABLE DURING ROUTINE INSPECTION. WE HEREBY REPORT THAT THE ALL PARTICULARS IN THIS REPORT ARE CORRECT AT THE TIME OF TEST / INSPECTION & OPERATIONAL MAINTENANCE IS THE SOLE RESPONSIBILITY OF THE EQUIPMENT OWNER.

THIS CERTIFICATE IS GENERATED AND AUTHORIZED ELECTRONICALLY AND CAN BE CONSIDERED AS ORIGINAL. TO VERIFY THE AUTHENTICITY OF THIS CERTIFICATE, PLEASE SCAN THE QR CODE.