



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	SAF-INS-2025-10-05070	Report Issue Date:	21-Oct-2025
Customer Name:	Sudhir Equipment Rental Company	Inspection Type:	Visual Inspection
Address:	Dammam , Kingdom Of Saudi Arabia.	Serial Number	VEPL/2021-22/0001
Site Location:	Zuluf	Equipment Id Number:	SG-515-40
Standard Reference:	ISO 8528-5:2022	Manufacturer:	VARADA ENERGIES
Inspection Date:	20-Oct-2025	Equipment Model/Type:	VEPL-40-CDP
Next Inspection Date:	19-Apr-2026	Sticker No:	SAF/004366

Description	Capacity/SWL	Reason For Examination	Result	Safe To Use
Engine Power Service Hours Engine Model Engine Make Manufacture Internal Visual Test Alternator Number General Surface Test Functional Check	LYHM111469 40 KVA 300 ALGPW4DE Leyland 2021 Satisfactory G21B055606 Satisfactory Satisfactory	40 KVA B	Satisfactory	YES

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
------------------	---------------	---------------	----------------	---------------------	-------------------------------	-------------------

Result	ACCEPTED	REJECTED (See Attached Defect Report)
--------	----------	--

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the inspection/examination and found to be free from any defect likely to affect safety.

Inspected By:		Approved By: BALAJI KRISHANAMOHAN	
Stamp By:		Designation: Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to Client equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.



VENDOR ID: 10044577



APPROVED VENDOR



VENDOR ID: 11052442



VENDOR ID: 5014041



VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882 / Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+ هاتف: 966 13 344 8882 / فاكس: 966 13 344 8881
+ هاتف: 966 13 367 0515
الموقع الإلكتروني: www.ui.com.sa

Doc No. UIC FMT 091-E/Rev No.-00



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

GENERATOR INSPECTION CHECKLIST						
Company:	Sudhir Equipment Rental Co.	Model Number:	VEPL-40-CDP			
Location:	Zuhuf	Manufacture Date:	2021			
Equipment Type		Serial No.:	VEPL/2021-22/0001			
Date:	20-06-2025	ID No.:	SG-515-40			
Capacity:	40KVA	Sticker No.:	SAF-004366			
Manufacturer:	VARADA					
#	INSPECTION ITEMS	Pass	Fail	N/A	COMMENT	
Sr.	GENERAL					
1.1	Last Third-party inspection Certificate / Sticker	✓				
1.2	Fire extinguisher in good condition and valid	✓				
1.3	Engine oil level	✓				
1.4	Water level	✓				
1.5	Fuel level	✓				
1.6	Fuel filter water drain	✓				
1.7	Battery & water	✓				
1.8	Leaks in oil system	✓				
1.9	Leaks in fuel system	✓				
1.10	Engine minimum and maximum speeds	✓				
1.11	Lifting eye	✓				
1.12	Tires and air pressure			✓		
1.13	Door hinges	✓				
1.14	Shutdown switches	✓				
1.15	Handle Lock Pin	✓				
1.16	Control panel gauges	✓				
1.17	Chawlyn valve	✓				
1.18	Emergency off Switch	✓				
1.19	Wheel Stopper			✓		
1.20	Earth Cable & Clamp	✓				

Inspected by: SDP

Signature: 

User Representative:

Signature, & Date: