



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

CERTIFICATE NO: UIC/JED/20139622

Customer : SUDHIR EQUIPMENT RENTAL COMPANY

Address : JEDDAH - KINGDOM OF SAUDI ARABIA.

Description : POWER GENERATOR

Manufacturer : VARADA ENERGIES

Model : N/A

Serial No. : TGFF5079N10935F

Equipment ID. No. : SG-518-400

Capacity : 400 Kva/320 kW

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection : 30-JAN-2024

Due Date : 29-JAN-2025

Additional Certification

Sticker Number: 107222

Inspected By:

Industrial Inspector



Approved By:

QA/QC Engineer

P.O.Box No.2072, Jubail-31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف : +٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس : +٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف : +٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/JED/20139622**Specifications:**

Prime Power	:	400kVA	Voltage	:	400V
Frequency	:	60 Hz	Power factor	:	0.8COS
Rated RPM	:	1000rpm			

Reference Standards:

NFPA 110

Comments & Recommendations:

The **Power Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Power Generator.
2. Inspect the Power Generator regularly for damage before every use.
3. Check oil level before operation of the Power Generator.
4. Check the condition of Control panel.
5. Check the operating characteristic before start the Power Generator.
6. Stop the engine before opening or removing engine covers.
7. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
8. **Remember – Safety always comes first!**

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer



No. 11659

Mr./Mrs: Sudhir Dental

Designation: _____

Date Of Calibration /Inspection : 30 / JAN / 2024

Tel. No.: _____

Calibration /Inspection Validity :_____6M / 1Y _____

Fax No.: _____

Location : _____

Calibration Engr Sign: S. Abdul Raik Name: S. Abdul Raik

(Client Sign) _____ Name: _____ Contact No: _____ Site Location: _____
 Witnessed & Approved by: _____