

Certificate of Visual Examination

Client Name :		
SUDHIR		
Work/ Rig Location:	Certificate Number:	Issued Sticker No.(if Applicable)
DAMMAM/ YARD	ZM-21-Z073- 302	w.6630
Date of Last Inspection	Date of Inspection:	Date of Next Inspection:
Sep -4-2020	7-Sep-2021	6-Sep-2022
Relevant Standards:		Color Code (If Applicable for the item)
ISO 8528-3		
Zamil Ref No.	Customer Requisition No.	
ZAM	N/A	


I.D. NUMBER	QTY	DESCRIPTION	SWL / CAPACITY
SG-526-650	1	Diesel Soundproof Generator	650 KVA
		Manufacturer: PERKINS	
		Model: VEPL-650-CDP	
		Serial Number: VEL/2021-22/0017	
		Engine Number: N21D178511/HCI534F1	
		Manufacturing Year: 2021	
NOTE : Visual Inspection & Functional Test Were Carried Out On The Above Mentioned Equipment , At The Time Of Inspection No Any Abnormality Found.			

Result: During the Time of Visual Inspection, Result found Satisfactory.

This Certificate by Company Under Its General Conditions of Services. This Issuance of This Certificate Does Not Exonerate the Buyers or Sellers from Exercising All Their Rights Discharging All Their Liabilities Under the Contacts of Sale. Stipulations to Contrary Are Not Binding on The Companies Responsibility Under This Certificates Is Limited to Proven Negligence and Will in No Case Be More Than Ten Times the Amount of The Free or Commission. The Above Findings Are Limited to Date Place of Intervention Only. The Company Is Neither an Insurer Not a Guarantor Disclaims All Liabilities in Such Capabilities.

Inspected By:
Name : YAZIED ALZAMIL
Qualifications : LEEA & ASNT NDT Level II Certified

Signature & Stamp:


طريق الملك فهد - حي الضباب - الدمام - س.ت: 2050069798 - ص.ب 419 - الدمام 31411

King Fahad Road - Al-Dhabab Avenue - Dammam - C.R.: 2050069798 - P.O. Box 419 - Dammam 31411 Email: info@zamil.sa