

SG-533-400

VARADA ENERGIES PVT LTD. (AN ISO 9001-2015 CERTIFIED COMPANY)

STANDARD- BS 5514

ISO- 8528

GENERAL INFORMATION

Customer Name

Customer Order No.

Test Cell No.

2

PRODUCT INFORMATION

Model	VEPL-400-CDP	Genset Serial No.	VEPL/2021-22/0027
Engine Serial No.	TGFF 5079N 11392G	Alternator Serial No.	N21H 325665
Brand Name	PERKINS	Alternator Make.	STAMFORD
Fuel Type	HSD	Controller Type	DEEP SEA
Governor Type	ELECTRONIC	Cooling System Type	WATER COOLED

TEST CONDITION

Altitude (Meters ASL)	1000	Oil Specifications	PERKINS MAKE
Ambient Temp. (C)	33	Humidity (%)	41
Air Filter Inlet Temp (C)	38	Coolant Mix	PERKINS MAKE

PRODUCT OPTIONS CHECKED

(e) Emergency Stop	(e) Panel Hooter	(e) Low Coolant Warning	(o) High Fuel S/Down
(e) Over Load Protection	(e) High Water Temp	(o) LET Warning	(o) High Fuel Warning
(e) Over Speed Protection	(e) Low Lub Oil Pressure	(o) Low Fuel S/Down	(e) Parallel Bus PT Module
(e) Under Voltage Protection	(e) Low Coolant S/Down	(e) Low Fuel Warning	(o) Earth Fault S/Down

TECHNICAL DATA (Declared)

Service Rating	400 kVA	Power Factor	0.8
Power Output (kW)	320	Rated Output (kW)	320
Rated Voltage (V)	400	Rated Current (A)	556
Frequency (Hz)	60	Speed (RPM)	1800
Number of Phases	3	Performance Class	H

TECHNICAL DATA (Measured)

Results (No Load)


Voltage	1 - 2 : 402 Volts	2 - 3 : 401 Volts	1 - 3 : 403 Volts
No Load Frequency	60	No Load Coolant Temp. (C)	73
No Load Lube Press	3.92 Bar		

Result (Full Load)

Voltage	1 - 2 : 405 Volts	2 - 3 : 404 Volts	1 - 3 : 400 Volts
Current	1 : 551 Amps	2 : 556 Amps	3 : 556 Amps
Full Load Frequency	60 Hz.	Full Load Coolant Temp. (C)	92
Full Load Lube Press	3.76 Bar	Power Factor	1.0
Prime set tested to 110% of Full Load (if required)		NA	

Date
RUN HOURS06.09.2020
60 mins

PANKAJ JOSHI- VARADA



56-533-h00

Engine Test Certificate

Perkins Engines Company Limited
Eastfield, Peterborough PE1 5FQ
Great Britain



4/8/2021

This engine has been tested to its maximum rating in accordance with Perkins defined requirements and had performed satisfactorily.

The electronics on this engine have been preset and when the engine has been run-in, the gross power output will be within +/-3% of the gross rating listed below, provided the exhaust and induction systems, fuel and lubricating oils are in accordance with Perkins defined requirements.

Engine Type	Engine Number	Build List	Customer
2206A-E13TAG5	TGFF5079N11392G	TGFF5079	Y932

Reference	Technical Data
Emissions Capability	UNREGULATED Low SFC
Engine Speed	50Hz @1500RPM
Engine Type	2206A-E13TAG5
Fuel Consumption - Prime Power	207 g/kWH
Fuel Consumption - Standby Max	203 g/kWH
Gross Engine Power - Prime Power	324.2 kW
Gross Engine Power - Standby Max	368.4 kW
Gross Rating	324.2 kW
Net Rating	305 kW

This engine was built and tested in accordance with our approved ISO 9001 Quality Procedure.

Performance certified as satisfactory.

Issue 5