


☐ Interim
☒ Final

INSPECTION REPORT

NO. R120211028.03

BV Job nr: KHO.INI.20.129.SA

PROJECT: Third Party Inspection for Diesel Powered Generator Set	Ref: KHO.INI.20.129.SA
BV Client: SUDHIR EQUIPMENT RENTAL	P/o nr: N/A (client to BV)
Manufacturer: VARADA ENERGIES PVT. LTD.	

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	QTY
Visual and functional examination of diesel powered portable generator set	VEPL/2021-22/0029 / SG-536-650	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No				
Title	Reference n°	Rev.	Approved by	Date
EQUIPMENT DATA SHEET	--	-	-	-

INSPECTIONS : <u>Inspection place & Date or Period:</u> DAMMAM, SUDHIR YARD OCT 28, 2021 <u>Stage of inspection :</u> ☐ Before manufacturing ☐ During manufacturing ☒ Final ☐ Packing <u>Type of inspection:</u> ☐ Pre-inspection meeting ☐ Document and QC record review ☒ Visual examination, checks ☐ Witnessing tests ☐ Manufacturing progress status ☐ Vendor assessment ☒ Final inspection ☐ Packing (for details see continuation sheet) <u>Stamping :</u> ☒ No ☐ ☐	<u>Results of inspection :</u> ☒ Satisfactory ☐ Unsatisfactory <u>Non Conformities Reports (NCR):</u> o NCR's issued during reported period : N/A o List of outstanding NCR's : N/A <u>Main Conclusions & Remarks:</u> (for details see continuation sheet) Third party visual inspection of 1 unit of diesel generator set was carried out and found satisfactory at the time of inspection. Valid Sticker Number: LFT-S. 01-28919 Next visit scheduled: OCT 27, 2022
---	---




☐ Interim
☒ Final

INSPECTION REPORT

NO. R120211028.03

BV Job nr: KHO.INI.20.129.SA

Description of the inspections carried out:**1. Introduction:**

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the general conditions which regulate the intervention of the society IVS-Lifting/B&F department at the request of Sudhir Equipment Rental Co. on the purpose of third party inspection of one diesel powered portable generator set with model number: **VEPL-650-CDP** and S/N: **VEPL/2021-22/0029**

2. Attendee(s):

Aslam

3. Scope of Inspection:

a. Visual Inspection & Functional Test of Diesel Generator Set

1- General Data

Equipment Type	Diesel Powered Generator Set
Manufacturer	VARADA ENERGIES PVT. LTD.
Model	VEPL-650-CDP
Engine Brand / Model / Serial Number	Perkins / 2800 Series / JGBF5005N07936F
Alternator Brand / Model / Serial Number	Stamford / HCI544F1 / N21I 357278
Generator Set Serial Number	VEPL/2021-22/0029
Year of Manufacturing	SEP 2021

2- Technical Specifications

Gen Set Mass	9800 kg
Electric DG Set Rating	650 kVA
Rated Power	520 kW
Power Factor (cos ϕ)	0.8
Voltage	400 V
Frequency	60 Hz



BUREAU
VERITAS
☐ Interim
☒ Final

INSPECTION REPORT

NO. R120211028.03

BV Job nr: KHO.INI.20.129.SA

3- Inspection and Test Results

Acceptance criteria	Result	Remarks
1. Document review, (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of unit-leaks, wear, damage, loose connection/components, corrosion.	Pass	Found in good condition.
3. Check fluids level (check for proper oil level and oil operating pressure, coolant level, etc).	Pass	Found in good condition.
4. Check air filter.	Pass	Found in good condition.
5. Electrical, (conduct general inspection of wiring and connection cable termination, corrosion, damage).	Pass	Found in good condition.
6. Prime mover / Generator (check for debris, foreign objects, loose or broken fittings; check guards and components; look for any unusual condition of vibration, leakage, noise, temperature or deterioration).	Pass	Found in good condition.
7. Check engine drive belts, fan coupling device-tension wear, whether cracking, damage.	Pass	Found in good condition.
8. Check emergency switches.	Pass	Found in good condition.

➤ Conclusion:

The generator set was found in good condition at the time of inspection.

Inspected by:

MOHAMMAD BENAFIF
IVS- Inspector

Checked by:

IVS- Inspection Team Leader

Date of issue: OCT 31, 2021

Inspection centre: BUREAU VERITAS ALKHOBAR

