

Engine Test Certificate	
Perkins 12/29/2020 Great Britain Eastfield, Peterborough PE1 5FQ Perkins Engines Company Limited 56-552-658	
This engine has been tested to its maximum rating in accordance with Perkins defined requirements and had performed satisfactorily. The electronics on this engine have been preset and when the engine has been run-in, the gross power output will be within +/-3% of the gross rating listed below, provided the exhaust and induction systems, fuel and lubricating oils are in accordance with Perkins defined requirements.	
Engine Type 2806A-E18TAG2	Engine Number JGBF5005N07928F
Build List JGBF5005	Customer Y932
Reference Technical Data UNREGULATED Low SFC 50Hz @1500RPM 2806A-E18TAG2 202 g/kWh 203 g/kWh 584 kW 628 kW 584 kW 565 kW	
Emissions Capability Fuel Consumption - Prime Power Fuel Consumption - Standby Max Gross Engine Power - Prime Power Gross Engine Power - Standby Max Gross Rating Net Rating	
This engine was built and tested in accordance with our approved ISO 9001 Quality Procedure. Performance certified as satisfactory.	
Issue 5	