



REPORT OF A THOROUGH EXAMINATION

Issue Date: 21-Jun-2026

Certificate Number: ECI/SA/C-03024/26 Rev. No: 00	Report Number: 132235	Sticker Number: 109567
Date of Thorough Examination: 20-Jun-2026	Date of Expiration: 19-Dec-2026	S.O.#: DMM/06-26/001 Ref.#: N/A

Client: SUDHIR EQUIPMENT RENTAL COMPANY	Address of Premises at Which the Examination Was Made: DAMMAM
---	---

Description and Identification of the Equipment:	Load Test Detail	Safe Working Load(s)	Applied Load(s)
Equipment / Type : INDUSTRIAL EQUIPMENT / AIR COMPRESSOR Location of the Equipment : DAMMAM YARD Equipment ID No : SAC-500-202 Equipment Serial No : PE2460170 Model : XAS 500-175 Manufacturer / Date of Manufacture : ATLAS COPCO / 2024 Applied Standard : BS EN 1012-1	N/A	12 BAR	N/A

Examination after installation / In-Services	Was the Examination carried out Within an interval of						
☐ Initial ☒ Periodic Inspection ☐ Re-Inspection after Major Repair / Modification Or Overhaul	☐ 3 Months ☒ 6 Months ☐ 12 Months ☐ After the exceptional circumstances						
Additional Information about the equipment and Information / Description of the Parts / attachments with the equipment. N/A							
Description of the Load Test : N/A							
Pre Load Test NDT done by : N/A	% of Load Applied : N/A	Post Load Test NDT done by : N/A		Expiration of Load Test : N/A			
Result				PASS	☒	FAIL	
Is the above a defect which is of immediate danger to persons?				YES		NO	☒
Is the above a defect which is not yet but could become a danger to persons?				YES by :		NO	☒
Particulars of any repair, renewal or alteration required to remedy the defect identified above: N/A							
Is this equipment safe to operate?				YES	☒	NO	

Note: We thus attest that the aforementioned equipment has undergone a thorough Visual Inspection and /or Functional Test conducted by a qualified inspector in accordance with Engineering Corner for Inspection (E.C.I.) procedure / local / international standards.

Liability: The client or this assignee or supervisor in interest agrees to identify and hold harmless **Engineering corner for inspection Co.Ltd.** from and against any all claims, demands, lawsuits or actions for damages including legal fees to persons and/or property tangible, intangible or otherwise which may be against, **Engineering corner for inspection Co.Ltd.** incidental to, arising out of or in connection with the work to be done, services to be performed or material to be furnished hereunder except for those claims caused solely and completely by the negligence of **Engineering corner for inspection Co.Ltd.** its directors, others, employees or sub-contractors.

Inspected by: MOHAMED ABDUL BARICK Signature:	Approved & Reviewed By: ALVARO 	QR Code:
--	--	--------------

	Engineering Corner for Inspection Company Limited INSPECTION CHECKLIST AIR COMPRESSOR	Doc. No.	ECIR - LFT - 39
		Rev. No.	01
		Rev. Date	17-FEB-2026
		Page No.	2 of 3

Issue Number : 02 & Issue Date : 03-FEB-2020

Equipment Owner	SUDHIR EQUIPMENT RENTAL COMPANY /	Report No. & Date	132235 20-Jun-2026
Manufacturer / Year	ATLAS COPCO / 2024	Location	DAMMAM YARD
Type / Model	INDUSTRIAL EQUIPMENT / AIR COMPRESSOR / XAS 500-175	Equipment ID. No.	SAC-500-202
Inspection Date	20-Jun-2026	Equipment Sr. No.	PE2460170
Inspector Name	MOHAMED ABDUL BARICK	Capacity / SWL	12 BAR
Standard	BS EN 1012-1	Expiration Date	19-Dec-2026

Item No	ITEM NAME	PASS	FAIL	N/A	Item No	ITEM NAME	PASS	FAIL	N/A
1	OEM certificates available	✓			11	Before any repair work is done on compressor pressure systems, is the pressure bled off and the system locked out?	✓		
2	Previous visual report or Certificate available	✓			12	Are signs posted to warn of a compressor's automatic starting feature?	✓		
3	NDT certificate	✓			13	Is the belt drive system enclosed to provide protection on the front, back, top, and sides?	✓		
4	Identification number / Serial number	✓			14	Are high-pressure hoses and connections in good repair?	✓		
5	Rated pressure / Capacity	✓			15	Before compressed air is used to empty containers of liquid, are the pressure limits of the containers checked?	✓		
6	Are compressors equipped with pressure-relief valves and pressure gauges?	✓			16	When compressed air is used with abrasive blast cleaning equipment, is the operating valve a type that must be held open manually?	✓		
7	Are compressor air intakes installed and equipped to ensure that only clean, uncontaminated air enters the compressor?	✓			17	If plastic piping is used, is the plastic approved for air line service? (some abs is ok - pvc is not.)	✓		
8	Are air filters installed on the compressor intake?	✓			18	Compressor / Pipe work / Fittings free from oil leaks	✓		
9	Are compressors operated and lubricated according to the manufacturers' recommendations?	✓			19	Are noise levels at site boundary within acceptable limits (45 dBA in built up residential area)	✓		
10	Are safety devices on compressed-air systems installed?	✓			20	Other visible defects	✓		

Overall Comments

Inspected By : MOHAMED ABDUL BARICK	Customer Representative : ARIF
--	---------------------------------------



ECL 109567

Capacity : 12 BAR

Equipment No. : SAC-500-202

Serial No. : PE2460170

Inspected Date : 20-Jun-2026

Next Inspection : 19-Dec-2026

Inspector : MOHAMED ABDUL BARICK

P.O.Box 235 Rastanura 31941 Kingdom of Saudi Arabia

Tel.: (013) 667-6999 / 667-6895 Fax #:(013) 667-6894

E-mail Address: eci@eccgroupksa.com