شركة مساندة الإعمار للفحص
Emaar Support Inspection Co.
6888, King Faisal Bin Abdul Aziz St, Ad Danah, Ras Tannurah, Saudi Arabia 32817
Tel : +966 507259023, +966 136670779, 055 8889186, 050 0484444
Email : info@esico.com.sa Website : www.esico.com.sa C.R : 2054100036

CERTIFICATE OF THOROUGH EXAMINATION AND / OR TEST OF GENERATOR SET

Date of thorough examination : 27-10-2026	Date of issue : 27-10-2026	Report No. : ESICO-LFT-R26-11041

Name & Address of employer	Location	Sticker	Standards
SUDHIR EQUIPMENT RENTALS	DAMMAM	12693	SASO ISO 12100

Equipment Identification No	Equipment Description	Safe Working Load(s)	Date of Manufacture	Manufacturer Name
SG-1363-500	DIESEL GENERATOR MODEL: SWB550GES POWER: 400KW RATED VOLAGE: 380/220 V RATED SPEED: 1800 RPM RATED CURRENT: 760 A PF: 0.8 FREQUENCY: 60 HZ	500 KVA	2025.05	SUPERMALY

Is this the first examination after installaton or assembly at a new site or location?	Yes	-	No	✗	Was the examination carried out within an interval of?	-	6 Months
If the answer to the above question is YES, has the equipment been installed correctly?	Yes	-	No	-	In accordance with an examination scheme?	Yes ✓	No -
					After the occurence of exceptional circumstances?	Yes -	No ✗

Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE	
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?	No
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)	Yes by : NONE
Particulars of any repair, renewal or alteration required to remedy the defect identified above : NONE	
Particulars of any tests carried out as part of the examination (if none state NONE) : NONE	
Observation/additional comments relative to this thorough examination : NO DEFECT FOUND AT THE TIME OF INSPECTION.	

For confirmation scan QR code
search with report number : ESICO-LFT-R26-11041

✓ Safe to operate

Next Inspection : 26-04-2027

Inspected by : ANSON