



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/RIY/20240707

Customer : Sudhir Equipment Rental Company

Address : Dammam, Kingdom of Saudi Arabia.

Description : Tower Light

Make : Varada Energies

Model : SGL-7.5

Serial No. : VEPL/2023-24/182

ID No. : STL-368

This is to certify that the equipment detailed hereby have been tested against traceable International Standards for VISUAL INSPECTION & FUNCTIONAL INSPECTION on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 22-MAR-2024

Due Date: 21-SEP-2024

Additional Certification

Sticker Number: 135182

Inspected By:



Industrial Inspector



Approved By:

[Signature]
QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٨٨٨٢ ٣٤٤ ١٣ / فاكس ٨٨٨١ ٣٤٤ ١٣ +٩٦٦

هاتف ٠٥١٥ ٣٦٧ ١٣ +٩٦٦

Certificate No: UIC/RIY/20240707**Engine Specifications:**

Product Description : 7.5kva
Product : SGL-7.5
Mass : 2800 kg

Inspection and Test

Internal visual Test : Satisfactory
General Surface Test : Satisfactory
Tower Light Shut-Down Test : Satisfactory

Comments & Recommendations:


The Mobile Tower Light was found to be of good working condition and reliable for safe operation.

- 1. At the time of inspection, the Mobile Tower Light was found satisfactory*
- 2. Avoid shock load of the Mobile Light Tower.*
- 3. On the Date of inspection, the equipment found to be of Good Construction, of adequate strength, in good working order and free from apparent defects that affect safe operation.*
- 4. Inspect the Mobile Tower Light regularly for damage before every use*
- 5. Always understand the operating procedure before using Mobile Tower Light*
- 6. Do not exceed the capacity of the Mobile Tower Light*
- 7. Remember – Safety always comes first!*

Inspected By:


Industrial Inspector

Approved By:


QA/QC Engineer