

INSPECTION CERTIFICATE

TOWER LIGHT

CLIENT NAME : SUDHIR EQUIPMENT RENTAL CO		WORK ORDER NO : WR-YAS-293		CERTIFICATE NO : YAS-CRT-960	
EQUIPMENT DESCRIPTION : ELECTRIC POWER TOWER LIGHT WITH A HEIGHT OF 8.5 METERS, EQUIPPED WITH TOWER LIGHTS POWERED BY A 7.5 KVA		CERTIFICATE NO : YAS-CRT-960		STICKER NO : 12843	
DATE OF INSPECTION : 25-Jan-2026		NEXT INSPECTION DUE : 24-Jul-2026			
PREVIOUS INSPECTION : 16-Jan-2025		PREVIOUS INSPECTION DETAILS : STANDARD ARABIA-121870			
MANUFACTURER : VARADA ENERGIES PVT LTD		MODEL/TYPE : SGL-7.5			
SERIAL NO : VEPL/2023-24/164		OWNER ID : STL-373			
CHECKLIST NO. : 0780		MANUFACTURED YEAR : 2023			
TYPE OF INSPECTION : VISUAL AND PERIODIC INSPECTION		LOCATION : RIYADH			
REFERENCE STANDARDS : ISO 8528-13:2016					
POWER		7.5 KVA			
NO OF LIGHTS		4			
MASS		2800KG			
Is this the first examination after installation or assembly at a new site or location ?		☐ Yes ☒ No		Within an interval of Months? ☒ 6 ☐ 12	
If the answer to the above question is YES has the equipment been installed correctly ?		☐ Yes ☒ No		In accordance with an examination scheme ? ☐ Yes ☒ No	
After the occurrence of exceptional circumstances ?		☐ Yes ☒ No			
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect: (If none state NONE)		NONE			
Is the above a defect which is of immediate danger to persons		☐ Yes ☒ No			
Is the above a defect which is not yet but could become a danger to persons:(If YES state the date by when)		NONE			
Particulars of any tests carried out as part of the examination: (If none state NONE)		NONE			
RESULT:		☒ PASS ☐ FAIL		IS THIS EQUIPMENT FIT FOR PURPOSE? ☒ Yes ☐ No	
REMARKS/RECOMMENDATION THIS IS TO CERTIFY THAT THE TOWER LIGHT HAS BEEN INSPECTED IN ACCORDANCE WITH INTERNATIONALLY RECOGNIZED STANDARDS FOR VISUAL AND PERIODIC ON THE INSPECTION DATE. THE EQUIPMENT IS FREE FROM EXTERNAL DAMAGE. DURING THE INSPECTION, THE EQUIPMENT IS FOUND TO BE SATISFACTORY.					
Date Of Report: 25/1/2026					

Approved By : ATHAR AZEEM




Authorized Inspector: AHAMED



Note : This certificate becomes void if the equipment is altered, repaired, or modified without authorization. The equipment owner is solely responsible for safe operation and maintenance. The company accepts no liability for damages or failures arising from negligence, poor maintenance, or conditions not detectable during routine inspection.

Branch of Electronics Components.co - Closed Joint Stock.co

✉ inspection@yastronics.net
info@yastronics.net

📞 920007296
yastronics.net



فرع شركة الرقائو الإلكترونية - شركة مساهمة مقفلة

سجل فرعي: 1010325658 رقم السجل الضريبي: 300047897800003

128379 ابي الحرم الكاتب حي جريز - الرياض 4499 المملكة العربية السعودية