

INSPECTION CERTIFICATE

TOWER LIGHT

CLIENT NAME : SUDHIR EQUIPMENT RENTAL CO.		WORK ORDER : WR-YAS-204	
EQUIPMENT DESCRIPTION : ELECTRIC POWER TOWER LIGHT WITH A HEIGHT OF 8.5 METERS, EQUIPPED WITH TOWER LIGHTS POWERED BY A 7.5 KVA		CERTIFICATE NO : YAS-CRT-587	
STICKER NO : 12539			
DATE OF INSPECTION : 21-Sep-2025		NEXT INSPECTION DUE : 20-Mar-2026	
PREVIOUS INSPECTION : 24-Dec-2024		PREVIOUS INSPECTION DETAILS : BUREAU VERITAS	
MANUFACTURER : VARADA ENERGIES PVT LTD		MODEL/TYPE : SGL-7.5	
SERIAL NO : VEPL/2023-24/166		OWNER ID : STL-377	
CHECKLIST NO. : 00440		MANUFACTURED YEAR : 2023	
TYPE OF INSPECTION : VISUAL AND PERIODIC INSPECTION		LOCATION : RIYADH	
REFERENCE STANDARDS : ISO 8528-13:2016			
POWER		7.5 KVA	
NO OF LIGHTS		4	
MASS		2800 KG	
FREQUENCY		60 HZ	
Is this the first examination after installation or assembly at a new site or location ?		☐ Yes ☒ No	
Within an interval of Months?		☒ 6 ☐ 12	
If the answer to the above question is YES has the equipment been installed correctly ?		☐ Yes ☒ No	
In accordance with an examination scheme ?		☐ Yes ☒ No	
After the occurrence of exceptional circumstances ?		☐ Yes ☒ No	
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect: (If none state NONE)		NONE	
Is the above a defect which is of immediate danger to persons		☐ Yes ☒ No	
Is the above a defect which is not yet but could become a danger to persons:(If YES state the date by when)		NONE	
Particulars of any tests carried out as part of the examination: (If none state NONE)		NONE	
RESULT:		IS THIS EQUIPMENT FIT FOR PURPOSE?	
☒ PASS ☐ FAIL		☒ Yes ☐ No	
REMARKS/RECOMMENDATION : THIS IS TO CERTIFY THAT THE TOWER LIGHT HAS BEEN INSPECTED IN ACCORDANCE WITH INTERNATIONALLY RECOGNIZED STANDARDS FOR VISUAL AND PERIODIC ON THE INSPECTION DATE. THE EQUIPMENT IS FREE FROM EXTERNAL DAMAGE. DURING THE INSPECTION, THE EQUIPMENT IS FOUND TO BE SATISFACTORY.			

Approved By : MUHAMMAD ATHAR AZEEM




Authorized Inspector: MUHAMMAD ADNAN



Note : This certificate becomes void if the equipment is altered, repaired, or modified without authorization. The equipment owner is solely responsible for safe operation and maintenance. The company accepts no liability for damages or failures arising from negligence, poor maintenance, or conditions not detectable during routine inspection.

Branch of Electronics Components.co - Closed Joint Stock.co

✉ Inspection@yastronics.net
info@yastronics.net

📞 920007296
yastronics.net



ISO 45001:2018
ISO 14001:2015

فرع شركة الرقائق الإلكترونية - شركة مساهمة مقفلة

سجل فرعي 1010325658 رقم السجل الضريبي : 300047897800003

128379 ابي الحرم الكاتب حي جريب - الرياض 4499 المملكة العربية السعودية