0500-4046 A0

DR. No.	LTR	No.	REVISION	CHK	DR	CHKD	APPROVED	DATE
DR49293	A	1	PRODUCTION RELEASE	-	SB	MR	WATSON	20/05/04
DR41921	B	1	DRG UPDATED TO SHOW CHANGE IN ALTERNATOR	TDH	CK	AM	MONNETT	08/11/05
		2	TABLE UPDATED TO SHOW CURRENT INFO	JYO	CK	AM	MONNETT	08/11/05
		3	DRG NUMBERS UPDATED TO SHOW CURRENT INFO	KE	CK	AM	MONNETT	08/11/05
		4	'C OF G'S' UPDATED	SID	CK	AM	MONNETT	08/11/05
		5	ALL GT DATA REMOVED FROM DRAWING	-	CK	AM	MONNETT	08/11/05





CONTAINER LIFTING REF - ISO 3674

THE CONTAINER IS DEFINED AS LOADED AND IS TO BE HANDLED BY THE SPECIFIED LIFTING METHODS SHOWN RIGHT.

TOP LIFT SPREADER - ISO 3874 CLAUSE 6.2



BOTTOM LIFT SLING - ISO 3874 CLAUSE 6.4
MINIMUM LIFTING ANGLE SHALL BE 30°



NOTES:

1. WEIGHT= SEE TABLE
2. CONTAINER LIFTING SEE - BS 3951 : PART1 : SECTION 1.2 : 1985
3. FOR CONSUMER UNIT CABLE CONNECTION USE CABLE TRAY RUNS
4. A DISTANCE OF 5M AROUND EACH END OF THE CONTAINER MUST BE KEEP CLEAR OF OBSTRUCTIONS
5. TERMS AND CONDITIONS CAN BE FOUND AT THE FOLLOWING :-
   www.cumminspower.com/terms









(B2) (B4)

ENGINE	ALTERNATOR	GENSET AND CONTAINER WT WEIGHT WITH WET ENGINE (DRY FUEL TANK) KG	RADIATOR	C of G
KTA50G3	P734B	17425	40°C	4988
KTA50G3	P734C	18083	40°C	4999
KTA50G3	P734D	18223	40°C	5012
KTA50G3	P734E	18309	40°C	5023
KTA50G8/GS8/G9	P734C	18518	40°C	4455
KTA50G8/GS8/G9	P734D	18818	40°C	4457
KTA50G8/GS8/G9	P734E	19144	40°C	4459
KTA50G8/GS8/G9	P734F	19340	40°C	4469
KTA50G8/GS8/G9	P734G	19554	40°C	4477

(B3) THIS DRAWING IS A LAYOUT REPESENTATION FOR THE FOLLOWING GENERATOR SETS.

- GENERATOR ASSY (P7B) WITHOUT RTD'S - DRG NO 0200-3133-01
- GENERATOR ASSY (P7C) WITHOUT RTD'S - DRG NO 0200-3133-02
- GENERATOR ASSY (P7D) WITHOUT RTD'S - DRG NO 0200-3133-03
- GENERATOR ASSY (P7E) WITHOUT RTD'S - DRG NO 0200-3133-04
- GENERATOR ASSY (P7F) WITHOUT RTD'S - DRG NO 0200-3133-05
- GENERATOR ASSY (P7G) WITHOUT RTD'S - DRG NO 0200-3133-06
- GENERATOR ASSY (P7B) RTD'S - DRG NO 0200-3133-07
- GENERATOR ASSY (P7C) RTD'S - DRG NO 0200-3133-08
- GENERATOR ASSY (P7D) RTD'S - DRG NO 0200-3133-09
- GENERATOR ASSY (P7E) RTD'S - DRG NO 0200-3133-10
- GENERATOR ASSY (P7F) RTD'S - DRG NO 0200-3133-11
- GENERATOR ASSY (P7G) RTD'S - DRG NO 0200-3133-12
- GENERATOR ASSY (P7B) WITH THERMISTORS - DRG NO 0200-3133-13
- GENERATOR ASSY (P7C) WITH THERMISTORS - DRG NO 0200-3133-14
- GENERATOR ASSY (P7D) WITH THERMISTORS - DRG NO 0200-3133-15
- GENERATOR ASSY (P7E) WITHOUT THERMISTORS - DRG NO 0200-3133-16
- GENERATOR ASSY (P7F) WITHOUT THERMISTORS - DRG NO 0200-3133-17
- GENERATOR ASSY (P7G) WITH THERMISTORS - DRG NO 0200-3133-18

THE COPYRIGHT OF THIS DRAWING
IS OWNED BY C.P.G. LTD.
AND IT MAY NOT BE PUBLISHED
OR REPRODUCED IN ANY MATERIAL
FORM WITHOUT THE WRITTEN CONSENT OF THE COMPANY

		NAME	DATE
TOLERANCE UNLESS OTHERWISE SPECIFIED	DRAWN TO -		
	COPIED FROM P6736800	DRAWN S WATSON	20/05/2004
DIM x ± 10.5 / x.x ± 10.25 / x.xx ± 10.13	THIRD ANGLE PROJECTION	CHECKED Michael Rose	28/07/2004
		APPROVED S WATSON	28/07/2004

AutoCAD | DO NOT SCALE PRINT | ANGLE TOL. ±1.0° | SCALE:

Cummins Power Generation
Columbus Avenue, Manston, Ramsgate
Kent, CT12 5BF, England, UK

TITLE: ENCLOSURE OUTLINE (KTA50)

SITE CODE: PGK | DRG NO: 0500-4046 | SHEET 1 of 1 | SIZE A0