



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



CERTIFIED
ISO 9001 : 2008
&
OHSAS 18001:2007

CERTIFICATE OF INSPECTION

Certificate No: UIC/20182127

Customer : Branch of Sudhir Gensets Limited.

Address : Dammam, Kingdom of Saudi Arabia

Description : Diesel Generator

Make : CUMMINS

Model : C250D5

Capacity : 250. KVA

Serial No : J12K408039

ID. No. : SG-002-250

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Testing : 27-Aug-2018

Due Date : 26-Aug-2019

Additional Certification

Sticker Number: 15088


Inspected By:

Industrial Inspector



Approved By:

QA/QC Engineer



P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦

Certificate No: UIC/20182127**Specification:**

Rated Power in kVA : 250 Kva - Power Factor : 1
 Speed : 1500 Rpm - Rated Frequency : 60 Hz
 Rated Voltage : 400 Volts : Rated Current : 360A

Engine Specification:

Engine Make : Cummins - Engine Model : 6CTAA8.3
 Serial Number : 22064966 - Rated Amps : 328 A
 Fuel Type : Diesel - Class : H
 Phase : 3

Reference Standards

BS 5000 Part 3 IEC 34-1 - Nema MG 1-3L ISO 8528-3
 BSEW 60034-1 :

Inspection and Test:

Internal Visual Test : Satisfactory - General Surface Test : Satisfactory
 Compressor Shut-Down : Satisfactory

Comments & Recommendations:

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the operating characteristic before start the Generator.
5. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
6. Remember - Safety always comes first!

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer