

CERTIFICATE OF THOROUGH EXAMINATION OF DIESEL GENERATOR

Date of thorough examination : 23-07-2025		Date of issue : 23-07-2025		Report No. : ESICO-LFT-R25-4953	
Name & Address of employer			Location	Sticker No	Standards
SUDHIR EQUIPMENT RENTALS COMAPNY			Riyadh	6605	SASO ISO 12100
Equipment Identification No	Equipment Description		Safe Working Load(s)	Date of Manufacture	Manufacturer Name
SG-021-125 OR 1404B266	DIESEL GENERATOR Rated power factor: 0.8 Rated frequency(Hz): 60 Rating voltage: 400 Rating KW:125KVA 32 PH: 3 Rating amps: 140 Mass: 2400 kg		N/A	2015	CUMMINS
Is this the first examination after installaton or assembly at a new site or location? Yes ☐ - ☐ No ☒			Was the examination carried out within an interval of? - 6 Months		
If the answer to the above question is YES, has the equipment been installed correctly? Yes ☐ - ☐ No ☐			In accordance with an examination scheme? Yes ☒ No ☐		
			After the occurence of exceptional circumstances? Yes ☐ - ☐ No ☒		
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE					
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?					N/A
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)			Yes by : N/A		
Particulars of any repair, renewal or alteration required to remedy the defect identified above : N/A					
Particulars of any tests carried out as part of the examination (if none state NONE) : NONE					
Observation/additional comments relative to this thorough examination : At the time of inspection generator was found to be of good condition and reliable for safe operation					



For confirmation scan QR code
search with report number : **ESICO-LFT-R25-4953**



☒ **Safe to operate**

Next Inspection : 22-01-2026

Inspected by : Mohamed Askar Ali

