

**Power
Generation****GENERATOR SET TEST CERTIFICATE**

Industrial Product Test Record Certificate of Test

Genset Load Testing -ISO 8528 Part-5

Date: 10-Oct-15

General Information

Customer: CME
Service Rating: Stand By Fuel Type: Diesel Type II

Product Information

Model: C300D6 3 Phase Genset Sr. No: J151801821
Governor Type: Electronic Controller Model: PC 1.2
Engine Sr. No: 84501202 Alternator Sr. No: N151392432
Cooling System Type: Mounted Radiator Genset KVA Rating: 375

Test Conditions

Altitude (m ASL): 663 Ambient Temp (°C): 30
Air Filter Inlet Temp (°C): 30-40 Fuel Oil Spec: ASTM D 975 No.2 Diesel Fuel
Coolant Mix: Ethylene Glycol+Water (1:1) Lube Oil Spec: SAE 15W40 API CI-4

Product Option Checked/Adjusted

Battery Charger	☒	3-Way valve	☒	HWT Shut down	☒
Coolant Heater	☒	Emergency Stop	☒	Controller	☒
EBS	☒	Governor	☒	Voltage Regulator	☒
PMG	☒	Remote Start	☒	Low Coolant sender	☒
Space Heater	☒	Oil Pressure Sender	☒	Low Coolant Shut Down	☒
Earth Fault Shut Down	☒	Oil Pressure Shut Down	☒	Low Fuel Level Warning	☒
Oil Temperature Heater	☒	HWT Sender	☒		

Technical Data- Declared

Power Output (KW): 300 Rated Current (A): 569.8
Rated Voltage (V): 380 Speed (RPM): 1800
Rated Output (KVA): 375 Power Factor: 0.8
Frequency (HZ): 60 Performance Class: G2

Technical Data - Measured (All Sets are tested at POWER FACTOR=1)

Observed Power	296.9	Corrected Power	300			
SET RESULTS NO LOAD CONDITION	Voltage L1-L2	380 V	Current L1	0 Amps	Frequency	60 HZ
	L2-L3	380 V	L2	0 Amps	Lube Pressure	543 Kpa
	L3-L1	380 V	L3	0 Amps	Coolant Temp	32 °C
	Load (KW)	0	RPM	1800		
SET RESULTS FULL LOAD CONDITION	Voltage L1-L2	382 V	Current L1	449 Amps	Frequency	60 HZ
	L2-L3	382 V	L2	449 Amps	Lube Pressure	331 Kpa
	L3-L1	382 V	L3	449 Amps	Coolant Temp	97 °C
	Load (KW)	296.9	RPM	1800		

Certified BY

Operator's Cummins WWID.

MV634

Cycle Duration
(in Hours.)

1.78

Format No. : QSF : E059:01

Power Generation Business Unit
Division of Cummins India Limited
Plot No. B2, SEZ Industrial Area
Vill : Survadi Nandal
Taluka Phaltan
Dist. Satara, Pin : 415523
cumminsindia.com

Registered Office
Cummins India Limited, Kothrud, Pune 411 038 Maharashtra, India
CIN : L29112PN1962PLC012276

1821

Our energy working for you.™



**Power
Generation**

Cummins India Ltd.

Power Generation Business Unit

Engine Test Certificate

This is to certify that Engine Model **QSL9-G5**

Serial Number **84501202**was tested using

Diesel as per ISO - 3046 Standard.

Corrected Full Load B.H.P. to N.T.P conditions as per the

test standard is **415 BHP** @ **1500RPM**

476 BHP @ 1800RPM

Date : / 10-Oct-15

Dehimbeller
Product Conformance