



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/RIY/20242699

Customer : Sudhir Equipment Rental Company
Address : Dammam, Kingdom of Saudi Arabia
Description : Generator
Make : CUMMINS
Model : C300D6(S)
Serial No : J151801821
Id No : SG-035-350
Capacity : 350 KVA

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Testing : 07-OCT-2024

Due Date : 06-APR-2025

Additional Certification

Sticker Number: 123568

Inspected By:



Industrial Inspector



Approved By:

[Signature]
QA/QC Engineer

Certificate No: UIC/RIY/20242699**Specification:**

Rated Power in KVA	:	350 KVA	-	Rated Frequency	:	60
Rated Power Factor	:	0.8	-	Year of Manufacture	:	2014
Rated Voltage	:	220Volts				
Speed	:	1800 Rpm				
Rated Current	:	984.1 Amps				

Inspection and Test:

Internal Visual Test	:	Satisfactory	-	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory				

Comments & Recommendations:

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check the condition of the nozzles regularly.
4. Check the condition of Radiator in equal interval.
5. Check the operating characteristic before start the Generator..
6. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
7. **Remember - Safety always comes first!**

Inspected By:

2
INSPECTOR
Industrial Inspector



Approved By:

QA/QC Engineer