

Certificate of Thorough Examination of Equipment

Name& address of Equipment owner		Location of inspection		Certificate No.	
Branch of Sudhir Gensets Limited		Dammam		IS0302204014	
ID NO.	Description of Equipment			SWL	Test Load
SG-045-150	GENERATOR Manufacturer : Cummins Serial No : K151408871 Model : C135D6(S)			N/A	N/A
Date of Inspection :	28-Oct-20	Date Of Next Inspection :	27-Oct-21	Sticker No.	0048423
Scope of Work :	Visual inspection	Functional test	Load test	Ref. Standard	
	Pass	Pass	N/A	BS EN ISO 12100-1 & NFPA 110	

Inspection Details

Visual & Functional inspection have been applied for the above description and
Found satisfactory at Time of Inspection.


Remarks (If Applicable) :

SAFE TO USE

TUV Rheinland Arabia certify that the item/s described herein were thoroughly examined and were found free from cracks , flaws, or other defects at the time of inspection unless otherwise stated above In remarks .

Inspector Name **Mohamed Hawana**

Signature




Checked by

Signature

