

**Power
Generation****GENERATOR SET TEST CERTIFICATE**

Industrial Product Test Record Certificate of Test

Date: 26-Sep-15

Genset Load Testing -ISO 8528 Part-5

General Information

Customer
Service Rating Fuel Type

Product Information

Model Genset Sr. No
Governor Type Controller Model
Engine Sr. No Alternator Sr. No
Cooling System Type Genset KVA Rating

Test Conditions

Altitude (m ASL) Ambient Temp (°C)
Air Filter Inlet Temp (°C) Fuel Oil Spec:
Coolant Mix: Lube Oil Spec:

Product Option Checked/Adjusted

Battery Charger ☒	3-Way valve ☒	HWT Shut down ☒
Coolant Heater ☒	Emergency Stop ☒	Controller ☒
EBS ☒	Governor ☒	Voltage Regulator ☒
PMG ☒	Remote Start ☒	Low Coolant sender ☒
Space Heater ☒	Oil Pressure Sender ☒	Low Coolant Shut Down ☒
Earth Fault Shut Down ☒	Oil Pressure Shut Down ☒	Low Fuel Level Warning ☒
Oil Temperature Heater ☒	HWT Sender ☒	

Technical Data- Declared

Power Output (KW) 135	Rated Current (A) 256.8
Rated Voltage (V) 380	Speed (RPM) 1800
Rated Output (KVA) 169	Power Factor 0.8
Frequency (HZ) 60	Performance Class G2

Technical Data - Measured (All Sets are tested at POWER FACTOR=1)

Observed Power 135.3	Corrected Power 135	
SET RESULTS NO LOAD CONDITION		
Voltage L1-L2 380 V	Current L1 0 Amps	Frequency 60 HZ
L2-L3 380 V	L2 0 Amps	Lube Pressure 582 Kpa
L3-L1 380 V	L3 0 Amps	Coolant Temp 31 °C
Load (KW) 0	RPM 1800	
SET RESULTS FULL LOAD CONDITION		
Voltage L1-L2 384 V	Current L1 205 Amps	Frequency 60 HZ
L2-L3 384 V	L2 205 Amps	Lube Pressure 490 Kpa
L3-L1 384 V	L3 205 Amps	Coolant Temp 75 °C
Load (KW) 135.3	RPM 1800	

Certified BY

KO198

Operator's Cummins WWID.

Cycle Duration
(in Hours.)

0.41

Format No. : QSF : E059:01

Power Generation Business Unit
Division of Cummins India Limited
Plot No. B2, SEZ Industrial Area
Vill : Survadi Nandal
Taluka Phaltan
Dist. Satara, Pin : 415523
cumminsindia.com

Registered Office
Cummins India Limited, Kothrud, Pune 411 038 Maharashtra, India
CIN : L29112PN1962PLC012276

Cummins India Ltd.

Power Generation Business Unit

Engine Test Certificate

This is to certify that Engine Model 6BTAA5.9-G6

Serial Number 84252538 was tested using


Diesel as per ISO - 3046 Standard.

Corrected Full Load B.H.P. to N.T.P conditions as per the

test standard is 195 BHP @ 1500RPM

215 BHP @ 1800RPM

Date : 26-Sep-15


Product Conformance