

**Power
Generation****GENERATOR SET TEST CERTIFICATE**

Industrial Product Test Record Certificate of Test

Genset Load Testing -ISO 8528 Part-5

Date: 26-Sep-15

General Information

Customer: CME
Service Rating: Stand By Fuel Type: Diesel Type II

Product Information

Model: C135D6 3 Phase Genset Sr. No: 1151408875
Governor Type: Electronic Controller Model: PC 1.2
Engine Sr. No: 84252544 Alternator Sr. No: N151392376
Cooling System Type: Mounted Radiator Genset KVA Rating: 169

Test Conditions

Altitude (m ASL): 663 Ambient Temp (°C): 30
Air Filter Inlet Temp (°C): 30-40 Fuel Oil Spec: ASTM D 975 No.2 Diesel Fuel
Coolant Mix: Ethylene Glycol+Water (1:1) Lube Oil Spec: SAE 15W40 API CI-4

Product Option Checked/Adjusted

Battery Charger	☒	3-Way valve	☒	HWT Shut down	☒
Coolant Heater	☒	Emergency Stop	☒	Controller	☒
EBS	☒	Governor	☒	Voltage Regulator	☒
PMG	☒	Remote Start	☒	Low Coolant sender	☒
Spqce Heater	☒	Oil Pressure Sender	☒	Low Coolant Shut Down	☒
Earth Fault Shut Down	☒	Oil Pressure Shut Down	☒	Low Fuel Level Warning	☒
Oil Temperature Heater	☒	HWT Sender	☒		

Technical Data- Declared

Power Output (KW): 135 Rated Current (A): 256.8
Rated Voltage (V): 380 Speed (RPM): 1800
Rated Output (KVA): 169 Power Factor: 0.8
Frequency (HZ): 60 Performance Class: G2

Technical Data - Measured (All Sets are tested at POWER FACTOR=1)

Observed Power	136	Corrected Power	135
SET RESULTS NO LOAD CONDITION	Voltage L1-L2 380 V	Current L1 0 Amps	Frequency 60 HZ
	L2-L3 380 V	L2 0 Amps	Lube Pressure 566 Kpa
	L3-L1 380 V	L3 0 Amps	Coolant Temp 33 °C
	Load (KW) 0	RPM 1800	
SET RESULTS FULL LOAD CONDITION	Voltage L1-L2 383 V	Current L1 204 Amps	Frequency 60 HZ
	L2-L3 383 V	L2 204 Amps	Lube Pressure 453 Kpa
	L3-L1 383 V	L3 204 Amps	Coolant Temp 78 °C
	Load (KW) 136	RPM 1800	

Certified BY

MV633

Operator's Cummins WWID.

Cycle Duration
(in Hours.)

0.41

Format No. : QSF : E059:01

Power Generation Business Unit
Division of Cummins India Limited
Plot No. B2, SEZ Industrial Area,
Vill : Survadi Nandal
Taluka Phaltan
Dist. Satara, Pin : 415523
cumminsindia.com

Registered Office
Cummins India Limited, Kothrud, Pune 411 038 Maharashtra, India
CIN : L29112PN1962PLC012276

Cummins India Ltd.

Power Generation Business Unit

Engine Test Certificate

This is to certify that Engine Model 6BTAA5.9-G6

Serial Number 84252544 was tested using


Diesel as per ISO - 3046 Standard.

Corrected Full Load B.H.P. to N.T.P conditions as per the

test standard is 195 BHP @ 1500RPM

215 BHP @ 1800RPM

Date : / 26-Sep-15


Product Conformance