



GENERATOR SET TEST CERTIFICATE

Industrial Product Test Record Certificate of Test

Genset Load Testing -ISO 8528 Part-5

Date: 16-Sep-15

General Information

Customer: CME
Service Rating: Stand By Fuel Type: Diesel Type II

Product Information

Model: C60D6 3 Phase Genset Sr. No: 1151210074
Governor Type: Mechanical Controller Model: PC 1.1
Engine Sr. No: FUY824700 Alternator Sr. No: G15E205388
Cooling System Type: Mounted Radiator Genset KVA Rating: 75

Test Conditions

Altitude (m ASL): 663 Ambient Temp (°C): 29
Air Filter Inlet Temp (°C): 30-40 Fuel Oil Spec: ASTM D 975 No.2 Diesel Fuel
Coolant Mix: Ethylene Glycol+Water (1:1) Lube Oil Spec: SAE 15W40 API CH-4

Product Option Checked/Adjusted

Battery Charger	☒	3-Way valve	☐	HWT Shut down	☒
Coolant Heater	☐	Emergency Stop	☒	Controller	☒
EBS	☐	Governor	☒	Voltage Regulator	☐
PMG	☐	Remote Start	☐	Low Coolant sender	☒
Space Heater	☐	Oil Pressure Sender	☒	Low Coolant Shut Down	☒
Earth Fault Shut Down	☐	Oil Pressure Shut Down	☒	Low Fuel Level Warning	☒
Oil Temperature Heater	☐	HWT Sender	☒		

Technical Data- Declared

Power Output (KW): 60 Rated Current (A): 114.0
Rated Voltage (V): 380 Speed (RPM): 1800
Rated Output (KVA): 75 Power Factor: 0.8
Frequency (HZ): 60 Performance Class: G2

Technical Data - Measured (All Sets are tested at POWER FACTOR=1)

Observed Power: 59.7 Corrected Power: 60

SET RESULTS NO LOAD CONDITION	Voltage	L1-L2 380 V	Current	L1 0 Amps	Frequency	62.4 HZ
		L2-L3 380 V		L2 0 Amps	Lube Pressure	656 Kpa
		L3-L1 380 V		L3 0 Amps	Coolant Temp	31 °C
	Load (KW)	0	RPM	1872		

SET RESULTS FULL LOAD CONDITION	Voltage	L1-L2 382 V	Current	L1 91 Amps	Frequency	60.1 HZ
		L2-L3 382 V		L2 91 Amps	Lube Pressure	537 Kpa
		L3-L1 382 V		L3 91 Amps	Coolant Temp	77 °C
	Load (KW)	59.7	RPM	1803		

Certified BY

NE791

Operator's Cummins WWID.

Cycle Duration
(in Hours.)

0.7

Format No. : QSF : E059:01

Power Generation Business Unit
Division of Cummins India Limited
Plot No. B2, SEZ Industrial Area
Vill : Survadi Nandal
Taluka Phaltan
Dist. Satara, Pin : 415523
cumminsindia.com

Registered Office
Cummins India Limited, Kothrud, Pune 411 038 Maharashtra, India
CIN : L29112PN1962PLC012276

Our energy working for you.™



Cummins India Ltd.

Power Generation Business Unit

Engine Test Certificate

This is to certify that Engine Model **S3.8G-10**

Serial Number **FUY824700**was tested using

Diesel as per ISO - 3046 Standard.

Corrected Full Load B.H.P. to N.T.P conditions as per the

test standard is **96 BHP** @ **1800RPM**

Date : 16-Sep-15

Sunil
Product Conformance