

**Power
Generation****GENERATOR SET TEST CERTIFICATE**

Industrial Product Test Record Certificate of Test

Genset Load Testing -ISO 8528 Part-5

Date: 18-Sep-15

General Information

Customer: CME
Service Rating: Stand By Fuel Type: Diesel Type II

Product Information

Model: C60D6 3 Phase Genset Sr. No: I151210121
Governor Type: Mechanical Controller Model: PC 1.1
Engine Sr. No: HUY831359 Alternator Sr. No: G151378443
Cooling System Type: Mounted Radiator Genset KVA Rating: 75

Test Conditions

Altitude (m ASL): 663 Ambient Temp (°C): 30
Air Filter Inlet Temp (°C): 30-40 Fuel Oil Spec: ASTM D 975 No.2 Diesel Fuel
Coolant Mix: Ethylene Glycol+Water (1:1) Lube Oil Spec: SAE 15W40 API CH-4

Product Option Checked/Adjusted

Battery Charger	☒	3-Way valve	☐	HWT Shut down	☒
Coolant Heater	☐	Emergency Stop	☒	Controller	☒
EBS	☐	Governor	☒	Voltage Regulator	☐
PMG	☐	Remote Start	☐	Low Coolant sender	☒
Space Heater	☐	Oil Pressure Sender	☒	Low Coolant Shut Down	☒
Earth Fault Shut Down	☐	Oil Pressure Shut Down	☒	Low Fuel Level Warning	☒
Oil Temperature Heater	☐	HWT Sender	☒		

Technical Data- Declared

Power Output (KW): 60 Rated Current (A): 114.0
Rated Voltage (V): 380 Speed (RPM): 1800
Rated Output (KVA): 75 Power Factor: 0.8
Frequency (HZ): 60 Performance Class: G2

Technical Data - Measured (All Sets are tested at POWER FACTOR=1)

Observed Power: 60.8 Corrected Power: 60

SET RESULTS NO LOAD CONDITION	Voltage	L1-L2: 380 V	Current	L1: 0 Amps	Frequency	63.1 HZ
		L2-L3: 380 V		L2: 0 Amps	Lube Pressure	596 Kpa
		L3-L1: 380 V		L3: 0 Amps	Coolant Temp	33 °C
	Load (KW)	0	RPM	1893		

SET RESULTS FULL LOAD CONDITION	Voltage	L1-L2: 383 V	Current	L1: 91 Amps	Frequency	60.2 HZ
		L2-L3: 383 V		L2: 91 Amps	Lube Pressure	470 Kpa
		L3-L1: 383 V		L3: 91 Amps	Coolant Temp	79 °C
	Load (KW)	60.8	RPM	1806		

Certified BY

MR217

Operator's Cummins WWID.

Cycle Duration
(in Hours.)

0.4

Format No. : QSF : E059:01

Power Generation Business Unit
Division of Cummins India Limited
Plot No. B2, SEZ Industrial Area
Vill : Survadi Nandal
Taluka Phaltan
Dist. Satara, Pin : 415523
cumminsindia.com

Registered Office
Cummins India Limited, Kothrud, Pune 411 038 Maharashtra, India
CIN : L29112PN1962PLC012276