

4640



**Power
Generation**

Cummins India Ltd.

Power Generation Business Unit

Engine Test Certificate

This is to certify that Engine Model **4BTAA3.3-G11**

Serial Number **P72025134** was tested using

Diesel as per ISO - 3046 Standard.

Corrected Full Load B.H.P. to N.T.P conditions as per the

test standard is..... **84** B.H.P. @ **1500** R.P.M.

Date :

28-12-2015


Product Conformance

A048U279

STAMFORD

Test Certificate

FOR

SALIENT POLE, SELF EXCITED / PMG EXCITED AND SELF REGULATED AC GENERATOR

Machine No. **G16A031391**

Type Test has been conducted on similar design machine

STANDARDS: Generator conforms to BS 5000 : Part 3, IS 4722

Tested in accordance with BS EN 60034 - 1

Rotor dynamically balanced to BS ISO 1940 - 1

ROUTINE TEST CERTIFICATE FOR BRUSHLESS AC GENERATOR:

FRAME: UCI224V1	AVR: SX460	AVR NO: 107496-1964	ENCLOSURE: IP23	
RATED KVA: 62.5	RATED VOLTS: 400	RATED AMPS: 87	FREQUENCY: 60	PHASE: 3
POWER FACTOR: .8	STR CONN: Series Star	STR WINDING: 311	RATING: Base Continuous	WIRE: 4-Wire
EXC. VOLTS: 58	EXC.AMPS: 2.3	AMB TEMP: 40		

FOR 3 PHASE SEQUENCE LOOKING FROM DRIVE END FOR CLOCKWISE ROTATION :U-V-W

WINDING	COLD RESISTANCE IN Ohm(+/- 10) AT 20°C (MAX VALUES)	INSULATION RESISTANCE (M- Ohm)	HV TEST 2KV FOR 1 MIN	INSULATION CLASS
STATOR	0.219	2+	OK	H
ROTOR	0.789	2+	OK	H

REGULATION TEST

FREQ.	VOLTS	AMPS	KVA	PF	KW	EXC.VOLT	EXC.AMP	% LOAD
62	401.4	0.00	0.00	0.00	0.00	12	.6	0.00
60	400	87	62.5	.8	50	58	2.3	100.00

REGULATION = (N.L.VOLTAGE-F.L.VOLTAGE / RATED VOLTAGE)*100 = 0.34 %

Item Description: AC Generator.UC22.4.V.1.311.1.3.11.5.SX460.Onan Green

Remarks:

Date: 21-JAN-16	Job No: 3350489-011	AUTHORISED SIGNATORY <i>mayer</i> Quality Assurance
-----------------	---------------------	---

Certificate Of ConformityQuality System Approval
ISO 9001/2008Frame Size : **UC1224V1**Serial Number : **G16A031391**

Manufactured Date : 21-JAN-16

KVA: **62.5**Authorised Signatory Quality Assurance: *mayer*

Electrical Test

Final Inspection

T01

T07

Date: 21-JAN-16

Suchir Gensets Ltd. ATHAL UNIT

suchir

Powering the Nation

Plot No. 8,9 & 10, Survey No. 144/1/2/1/2
& 144/1/2/1/3 & 144/1/2/10. Athal Industrial Estate, Village - Athal.
Post. Naroli, Silvassa. (U. T. of D & N.H.) Tel.: (0260) 3291420 / 21

TEST CERTIFICATE FOR ELECTRIC DIESEL GENERATING SET

This is to certify that 62.5 KVA Diesel Generating Set

S. R. No. 4670 has been tested at our works as per

ISO : 8528. The performance of the set was found electrically
and mechanically sound and in working order in all particulars.

The set was coupled with the following major components.

Engine Make :

Comair

Engine Model : 4B70A9.3611

Engine Sr. No. : P2025134

Alternator Make :

Stohel

Frame Size : W124M

Alternator Sr. No. : C16A031391


(Authorised Signatory)
(Q. A & C.)