



Production Test Certificate

General Information

WIP Job No:	13439932	Customer Order No:	UNASSIGNED
Customer Name:	UNASSIGNED	Test Cell No:	5

Product Information

Model:	C450 D6E	Genset Serial No:	J15K880798
Engine Serial No:	79868681	Alternator Serial No:	A15J400115
Fuel Type:	DIESEL	Controller Type:	PC2.2
Governor Type:	Electronic	Radiator Serial No:	N/A
Cooling System Type:	Mounted Radiator	Controller Serial No:	0052964112

Test Conditions

Altitude (Meters ASL):	32	Barometric Pressure(mB):	1018
Ambient Temp(C):	14	Humidity(%):	24
Fuel Oil Spec:	BS 2869 Class A2	Lub Oil Spec:	Premium Blue 15W40
Fuel Density(kg/m):	820 - 875	Fuel Calorific Value:	43500 kJ/kg
Air Filter Inlet Temp(C):	14	Coolant Mix:	50/50 - Ethylene Glycol/Water

Product Options Checked

☒ Emergency Stop	Panel Heater	☒ Low Coolant S/Down	Low Fuel S/Down	High Fuel Warning
☒ Remote Start	Alternator Heater	Low Coolant Warning	Low Fuel Warning	Parallel Bus PT Module
Coolant Heater	Run Relay	☒ LET Warning	High Fuel S/Down	Earth Fault S/Down
CCB Trip Warning				

Technical Data - Declared

Service Rating:	STANDBY	Power Factor:	0.8
Power Output(kW):	450	Rated Output(kVA):	562
Rated Voltage(V):	380	Rated Current(A):	854
Frequency(Hz):	60	Speed(RPM):	1800
Number Of Phases:	3	Performance Class:	G2
Meter Serial No:	16065		

Technical Data - Measured

Results(No Load)

Voltage:	1-2:	383	Volts	2-3:	383	Volts	1-3:	383	Volts
	1-N:	222	Volts	2-N:	222	Volts	3-N:	222	Volts
No Load Freq:	60	Hz					No Load Coolant Temp(C):	76	
No Load Lube Press:	3.3	Bar							

Results(Full Load)

Voltage:	1-2:	380	Volts	2-3:	380	Volts	1-3:	380	Volts
	1-N:	220	Volts	2-N:	220	Volts	3-N:	220	Volts
Current:	1:	684	Amps	2:	684	Amps	3:	684	Amps
Full Load Frequency:	60	Hz	Full Load Coolant Temp(C):	80		Power Factor:	1.0		
Full Load Lube Press:	2.9	Bar	Prime set tested to 110% of Full Load(if reqd):	N/A					

PTI/Static Test Completed By:	Pete Ayles	Date:	15-OCT-15	Run Hours:	0.85
Dynamic Test Completed By:	Norman Phillips	Date:	15-OCT-15		

Cummins Power Generation Ltd.
Manston Park, Columbus Avenue
Ramsgate, Kent
CT12 5BF, United Kingdom
Tel :+44 1843 255000
Fax :+44 1843 255902