



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20243827

Customer : Sudhir Equipment Rental Company
Address : 2nd Industry Dammam, Kingdom of Saudi Arabia.
Description : Generator
Make : PERKINS
Model : 2206A-E13TAG3
Serial Number : TGDF5136N03048B
ID Number : SG-144-400
Rated Power : 349 kW

This is to certify that the description detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 06-JUN-2024

Due Date: 06-DEC-2024

Additional Certification

Sticker Number: 150590

Inspected By:

Industrial Inspector



Approved By:

[Signature]
QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤
هاتف ٠٥١٥ ١٣ ٣٦٧

Certificate No: UIC/DAM/20243827**Specification:**

Rated Power in HP	:	468 HP	-	Speed	:	1800 RPM
Rated Frequency	:	60 Hz	-	Rated Voltage	:	380 V
Phase	:	3	-	Power Factor	:	0.80

Inspection and Test:

Internal Visual Test	:	Satisfactory	-	General Surface Test	:	Satisfactory
Shut-Down	:	Satisfactory				

Comments & Recommendations:

The **Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Check the operating characteristic before start the Generator.
7. Stop the engine before opening or removing engine covers.
8. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
9. **Remember - Safety always comes first!**

Inspected By:

UIC
21
Industrial Inspector

**Approved By:**

QA/QC Engineer

No. 25456

Company Name & Address of the Site Location:

Company / Customer Name: Sudhica

Purchase Order No. : _____

Mr. /Mrs: Equipment

Date Of Calibration / Inspection : 06-Jun-2024

Mobile/Tel. No.: Rental

Calibration / Inspection Validity : 6m 6M / 1Y _____

Email ID : _____

Location : Dammam

2nd Industry

[illegible]

Cal. Engr/Insp. Sign: Name: M. W. Sims

(Client Sign) _____ Name: _____

Contact No: _____ Site Location: Damme

Witnessed & Approved by