


☐ Interim
☒ Final

INSPECTION REPORT

NO. R115211102.02

BV Job nr: KHO.INI.19.206.SA.

PROJECT: Third Party Inspection for GENERATOR	Ref: KHO.INI.19.206.SA.
BV Client: Sudhir Rentals	P/o nr: N/A (client to BV)
Manufacturer: ASHOK LEYLAND	P/o nr: N/A (client to Manufacturer)

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	Owner ID No.:	QTY
VISUAL EXAMINATION AND FUNCTIONAL TEST OF GENERATOR	VEPL/2017/18-0037	SG-150-60	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No

Title	Reference n°	Rev.	Approved by	Date
ORIGINAL DECLARATION OF CONFORMITY	AL4DTIG3	-	ASHOK LEYLAND	N/A

INSPECTIONS :

Inspection place & Date or Period:
 Sudhir Rental Warehouse,
 HARADH

02 , NOV , 2021

Stage of inspection :

- ☐ Before manufacturing
☐ During manufacturing
☒ Final
☐ Packing

Type of inspection:

- ☐ Pre-inspection meeting
☐ Document and QC record review
☒ Visual examination, checks
☐ Witnessing tests
☐ Manufacturing progress status
☐ Vendor assessment
☒ Final inspection
☐ Packing

(for details see continuation sheet)

Stamping :☒ No☐☐**Results of inspection :** ☒ Satisfactory ☐ Unsatisfactory**Non Conformities Reports (NCR):**

o NCR's issued during reported period : N/A

o List of outstanding NCR's : N/A

Main Conclusions & Remarks: (for details see continuation sheet)

Third party visual inspection of 1 unit of GENERATOR
 was carried out and found satisfactory at the time of Inspection.

Valid Sticker Number : 01-29023**Next visit scheduled:** 01 , MAY , 2022


☐ Interim
☒ Final

INSPECTION REPORT

NO. R11521102.02

BV Job nr: KHO.INI.19.206.SA.

Description of the inspections carried out:**1. Introduction:**

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the General condition which Regulate the intervention of the society IVS-Lifting/B&F Department at the Request of Sudhir Rentals on the purpose of Third Party Inspection .

2. Scope of Inspection :

a. Visual Inspection & Functional Test of GENERATOR

1- General Data

Equipment Type	Diesel Soundproof Generator
Manufacturer	ASHOK LEYLAND
Model	AL4DTIG3
Serial No.	VEPL/2017/18-0037
Owner ID No	SG-150-60
RATING	65.5 KVA / 50KW
FREQUENCY	60 HZ

2- Inspection and Test Results


Acceptance criteria	Result	Remarks
1. Document review (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of Unit, wear, damage, loose connection /components, corrosion.	Pass	Found good condition.
3. Electrical,(conduct general inspection of wiring and connection cable termination, corrosion, damage	Pass	Found good condition.

➤ Conclusion:

The GENERATOR found in good condition at the time of Inspection.

Inspected by:

AHMED TAHER
EQUIPMENT INSPECTOR



Checked by:

OPERATION TEAM LEADER

Issued at Al Khobar office on 03 , NOV , 2021