

**VARADA ENERGIES PVT LTD. -- PRODUCT TEST CERTIFICATE**

**GENERAL INFORMATION**

|               |  |                    |   |
|---------------|--|--------------------|---|
| Customer Name |  | Customer Order No. |   |
|               |  | Test Cell No.      | 1 |

**PRODUCT INFORMATION**

|                   |               |                       |                   |
|-------------------|---------------|-----------------------|-------------------|
| Model             | VEPL-40-CDP   | Genset Serial No.     | VEPL/2017-18-0043 |
| Engine Serial No. | HBHM 419898   | Alternator Serial No. | LBS3F17G10986-H   |
| Brand Name        | Ashok Leyland | Alternator Make.      | Leroy Somer       |
| Fuel Type         | HSD           | Controller Type       | DEEP SEA          |
| Govoner Type      | MECHANICAL    | Cooling System Type   | WATER COOLED      |

**TEST CONDITION**

|                           |      |                    |                               |
|---------------------------|------|--------------------|-------------------------------|
| Altitude (Meters ASL)     | 1000 | Oil Specifications | Ley Power 15 W 40 - Synthetic |
| Ambient Temp. (C)         | 38   | Humidity (%)       | 38                            |
| Air Filter Inlet Temp (C) | 42   | Coolant Mix        | 50 : 50                       |

**PRODUCT OPTIONS CHECKED**

|                              |                          |                         |                            |
|------------------------------|--------------------------|-------------------------|----------------------------|
| (●) Emergency Stop           | (o) Panel Heater         | (o) Low Coolant Warning | (o) High Fuel S/Down       |
| (●) Over Load Protection     | (●) High Water Temp      | (●) LET Warning         | (o) High Fuel Warning      |
| (●) Over Speed Protection    | (●) Low Lub Oil Pressure | (o) Low Fuel S/Down     | (o) Parallel Bus PT Module |
| (●) Under Voltage Protection | (o) Low Coolant S/Down   | (o) Low Fuel Warning    | (o) Earth Fault S/Down     |

**TECHNICAL DATA (Declared)**

|                   |        |                   |      |
|-------------------|--------|-------------------|------|
| Service Rating    | 40 kVA | Power Factor      | 0.8  |
| Power Output (kW) | 32     | Rated Output (kW) | 32   |
| Rated Voltage (V) | 400    | Rated Current (A) | 45   |
| Frequency (Hz)    | 60     | Speed (RPM)       | 1800 |
| Number of Phases  | 3      | Performance Class | H    |

**TECHNICAL DATA (Measured)**

**Results (No Load)**

|                    |                   |                           |                   |
|--------------------|-------------------|---------------------------|-------------------|
| Voltage            | 1 - 2 : 402 Volts | 2 - 3 : 401 Volts         | 1 - 3 : 403 Volts |
| No Load Frequency  | 62                | No Load Coolant Temp. (C) | 71                |
| No Load Lube Press | 3.90 Bar          |                           |                   |

**Result (Full Load)**

|                                                     |                   |                             |                   |
|-----------------------------------------------------|-------------------|-----------------------------|-------------------|
| Voltage                                             | 1 - 2 : 405 Volts | 2 - 3 : 404 Volts           | 1 - 3 : 400 Volts |
| Current                                             | 1 : 45 Amps       | 2 : 46 Amps                 | 3 : 43 Amps       |
| Full Load Frequency                                 | 60 Hz.            | Full Load Coolant Temp. (C) | 88                |
| Full Load Lube Press                                | 3.78 Bar          | Power Factor                | 1.0               |
| Prime set tested to 110% of Full Load (if required) |                   | NA                          |                   |

|           |  |           |           |
|-----------|--|-----------|-----------|
| Tested By |  | Date      | 26-Jul-17 |
|           |  | RUN HOURS | 45 mins   |

