



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	DAM-INS-2026-03-15340	Report Issue Date:	19-Mar-2026
Customer Name:	Sudhir Equipment Rental Co.	Inspection Type:	Visual Inspection
Address:	Dammam	Serial Number	PW62.5M3T25-01891
Site Location:	Abqaiq	Equipment Id Number:	SG-1554-60
Standard Reference:	ISO 8528-5:2022	Manufacturer:	Powerol
Inspection Date:	18-Mar-2026	Equipment Model/Type:	DG.62.5M3.S.E.B193
Next Inspection Date:	17-Sep-2026	Sticker No:	DAM/011126


Description		Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Frequency	60 Hz	Rated Power - 60 KVA	B	Satisfactory	YES
Rated Voltage	400 V				
Rated Speed	1800 RPM				
Phase& Power Factor	3 & 0.8 Φ				
Fluid Levels & Systems	Satisfactory				
Electrical & Battery	Satisfactory				
Control Panel & Grounding	Satisfactory				
Mechanical & Physical Condition	Satisfactory				
Emergency stop button	Satisfactory				
Fire extinguisher	Satisfactory				
Internal Visual Test	Satisfactory				
General Surface Test	Satisfactory				

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
------------------	---------------	---------------	----------------	---------------------	-------------------------------	-------------------

Result	ACCEPTED	REJECTED (See Attached Defect Report)
--------	----------	--

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than theses detailed above.

Inspected By:		Approved By:	Signature:
Stamp By:		JASIM KHAN	
		Designation:	
		Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to client-owned /to be rented equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.

أرامكو السعودية
saudi aramco
VENDOR ID: 1004457

The Red Sea
Development
Company
APPROVED VENDOR

سابك
SABIC
VENDOR ID: 11052442

الشركة العالمية للتفتيش المحدودة
Saudi Electricity
VENDOR ID: 5014041

MA'ADEN
Saudi Arabian Mining Company
VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882/Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+هاتف: 966 13 344 8882 / فاكس: 966 13 344 8881
+هاتف: 966 13 367 0515
الموقع الإلكتروني: www.ui.com.sa

Doc No. UIC FMT 091-E/Rev No.-00