



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	DAM-INS-2026-03-16063	Report Issue Date:	30-Mar-2026
Customer Name:	Sudhir Equipment Rental Co.	Inspection Type:	Visual Inspection
Address:	Dammam	Serial Number	PW62.5M3K25-03286
Site Location:	Jafurah	Equipment Id Number:	SG-1619-60
Standard Reference:	ISO 8528-5:2022	Manufacturer:	Powerol
Inspection Date:	28-Mar-2026	Equipment Model/Type:	DG.62.5M3.S.E.B193
Next Inspection Date:	27-Sep-2026	Sticker No:	DAM/011602

Description	Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Frequency	60 Hz	B	Satisfactory	YES
Rated Voltage	400 V			
Rated Speed	1800 RPM			
Phase & Power Factor	3 & 0.8 Φ			
Fluid Levels & Systems	Satisfactory			
Electrical & Battery	Satisfactory			
Control Panel & Grounding	Satisfactory			
Mechanical & Physical Condition	Satisfactory			
Emergency stop button	Satisfactory			
Fire extinguisher	Satisfactory			
Internal Visual Test	Satisfactory			
General Surface Test	Satisfactory			

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
------------------	---------------	---------------	----------------	---------------------	-------------------------------	-------------------

Result	ACCEPTED	REJECTED (See Attached Defect Report)
--------	----------	--

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the inspection/examination and found to be free from any defect likely to affect safety other than those detailed above.

Inspected By:		Approved By:	
Stamp By:		Designation:	
		Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.



VENDOR ID: 1004457



APPROVED VENDOR



VENDOR ID: 11052442



VENDOR ID: 5014041



VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882/Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+هاتف: 966 13 344 8882 / فاكس: 966 13 344 8881
+هاتف: 966 13 367 0515
الموقع الإلكتروني: www.ui.com.sa

Doc No. UIC FMT 091-E/Rev No.-00