



EMISSION TEST CERTIFICATE

Certificate No.	: EMSCRT18051	Test Date	: 03-DEC-2025
Issue Date	: 03-DEC-2025	Due Date	: 02-JUNE-2026
Work Order No.	: INSJO11594	Test Location	: JEDDAH

CUSTOMER NAME	SUDHIR EQUIPMENT RENTAL
----------------------	--------------------------------

EQUIPMENT DETAILS

EQUIPMENT NAME / ASSET ID	GENERATOR - SG-1087-350
MANUFACTURER	VARADA
MODEL	VEPL-350-CDP
SERIAL NUMBER	VEPL/2024-25/213
MANUFACTURER YEAR	2024

REFERENCE PROCEDURE	NA	RESULT	PASS
ACCEPTANCE VALUE	(± 2%)		

MASTER EQUIPMENT USED

DESCRIPTION	MODEL/TAG NUMBER	TRACEABILITY
GAS ANALYZER	SKY8000-M5-X	INTERNATIONAL SYSTEM OF UNIT(SI)

UV GULF Inspection & Training & calibration Services here by certifies that the instrument above mentioned has been calibrated using standard specifications as stated in the reference calibration procedure/guideline/international standard in accordance with the quality system conform to ISO/IEC 17025:2017 and ISO 9001:2015 Pass/fail of the instrument is determined based on manufacturer specifications or customer requirements.

The Readings given are the results at the time of calibration and do not carry any implication regarding the long-term stability of the instrument UV GULF recommends recalibration of this instrument as per the manufacturers' specifications/client's requirements/standard practices.

Reported expanded uncertainty is based on a combined uncertainty multiplied by a coverage factor K=2, providing the level of confidence of approximately 95% (This statement is only applicable if the datasheet contains uncertainty estimation).

This certificate is only issued for the instrument described above and is not applicable to anything else. The certificate is considered invalid unless it has the authorized signature and stamp of the UV GULF Inspection & Training & calibration.



EQUIPMENT : GENERATOR	CERT NO : INCRT18051
S.R. NO : VEPL/2024-25/213	TEST DATE : 03-DEC-2025

TEST RESULTS

TYPE	CONN	STAT	UNIT	RESULT
CO	187	NO	PPM	PASS
SO2	0	NO	PPM	PASS
NOx	137	NO	PPM	PASS
O2	15.78	AH	%VOL	PASS
CO2	3.88	AH	%VOL	PASS

REMARK: -

1. The above equipment was tested at the Site.
3. The measurement confidence level is 96.95%
4. The above results relate only to the items tested.

Tested By:
Nikhil Kumar Sinha




Approved By:
SAYED RAFIK ABDULLAH



This is e-certificate generated and authorised electronically & can be considered as original. To verify the authenticity of his e-certificate please scan the provided QR Code

No liabilities will be considered against UV Gulf Co. Ltd, for failure, damage or other occurrence to client owned or operated equipment due to misuse, improper installation, poor maintenance, environmental condition, nature disaster, operator mistakes and uncontrolled operation. The concerned inspector or representative has thoroughly examined the item in accordance with relevant standards. Inspection indicates that the mentioned item/machine/tools has no apparent defects which may prove dangerous during normal operation and it's found satisfactory for further use under specified manufacturer manual/guide and operated by a certified operator. This certificate shall not be generated without an official approval in between UV Gulf and Client. This Certificate becomes invalid if any modification/alteration is made to the item.