



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO : UIC /TAB / 1155

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer : SUDHIR EQUIPEMENT RENTAL COMPANY

Address : Tabuk, Kingdom of Saudi Arabia.

Description : Pressure Relief Valve

Manufacturer : HARSHAD

Model : 9095799400

Receipt Date : 29-Nov-25

Serial No. : 2408700

Calibration Date : 29-Nov-25

ID No : SAC-250-256

Calibration Due Date : 28-May-26

Location : Calibration Lab (Tabuk)

Issue Date : 30-Nov-25

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements


Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Compactor	N25-1463	214E2207020	5-Feb-26
Digital Pressure Calibrator	N25-3029	710190423	19-Apr-26

Calibrated By



Calibration Engineer



Approved By

[Signature]
QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٥١٥ ١٣ ٩٦٦

CERTIFICATE NO : UIC /TAB / 1155

Customer	SUDHIR EQUIPEMENT RENTAL COMPANY		
Address	Tabuk, Kingdom of Saudi Arabia.		
Description	Pressure Relief Valve		
Manufacturer	HARSHAD	Calibration Date	29-Nov-25
Model	9095799400	Calibration Due Date	28-May-26
Serial No.	2408700	Temperature	23.1°C
ID No	SAC-250-256	Relative Humidity	RH 53%

Test Results

Set Pressure :	9.50	BAR		Spring No./ Press. Range:	-----
Back Pressure	0	BAR		Size Inlet / Outlet :	3/4"
CDTP	9.50	BAR		Type of Valve :	Metal Seated
Setting Accuracy : ± 3 % of Setting				Test Medium :	Air/Gas/Water/Oil
Pop Test : PASSED					

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed below for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)

No

The instrument was adjusted

Yes

The instrument was repaired

No

Calibrated By:



Calibration Engineer



Approved by:

QA/QC Engineer