



INSPECTION REPORT OF THOROUGH VISUAL EXAMINATION & TEST OF IN-SERVICE INDUSTRIAL AIR COMPRESSOR

Time Sheet No: **14172** / Job Order No. **10194**

Sticker No. **14555**

Certificate No.: **AI-CERT-FK-641**

Name & Address of the Owner of the Equipment SUDHIR EQUIPMENT RENTALS CO, KSA			
Name & Address of the Maker or Supplier of the Equipment ATLAS COPCO		Location of Survey TABUK YARD-KSA	
Type of Pressure Equipment: AIR COMPRESSOR	Type of Examination Thorough Visual Examination	Relevant Standard BS EN 1012-1:2010 PROCEDURE NO: AI/IP/41	
Scope of Inspection:			
1- Visual Inspection of Air Compressor, Receiver & Pressure Gauge.... etc.		Satisfactory	
2- Thickness Measurement for The Shell Plate and dish head.		Satisfactory	
3- Functional Test.		Satisfactory	
4- NDT Test.		NA	
5- Hydro/ Pneumatic Test.		N.A.	
Equipment Technical Specification:			
Compressor		Air Vessel	
Manufacturer	ATLAS COPCO	Serial No.	PE2470680
Model	XAS 250-100	CFM	250
Colour	Yellow	Pressure Range	7.0 bar
Asset No.	SAC-250-292	Year	2024
Others:			
Date of last major repair	NIL	Date of Last NDT	NIL
Date of Latest Inspections	NIL	Functionally	Status:
1. On 01/11/2025 the above-indicated equipment was inspected, & the outcome is: 2. We kindly advise you that the mentioned items in section "A" (<i>see overleaf</i>) have to be repaired without delay. 3. The recommendations and remarks are for information only. We recommend the implementation of measures in the medium term or together with a major modernization. 4. Maintaining safety valve and pressure gauge calibration is the owner/user's responsibility. 5. The inspection certificate shall not be valid in case of inspected equipment is subjected to a major repair or/and the safety valves calibration is not maintained during inspection certificate validity. 6. This certificate is valid for 12 months (The next inspection is due on 30/04/2026) from the date of inspection. It doesn't cover any after-effects due to dismantling, alterations, or repairs.			

Head Office Address:
ALLIANCE INFINITE LLC 5900 BALCONES DRIVE STE 4147 AUSTIN TEXAS 78731 USA
T: +1 979-328-1759
E: info@allianceinfinite.com
W: www.allianceinfinite.com
Bahrain Office Address:
Gems Tower, Hidd, Bahrain
KSA Office:
Al Mergab Tower, 9th floor 9b, Jubail, KSA
AI/1252/12/REV.01 – 01/10/1998 ©
TECHUVI/1252/12/REV.01 – 01/10/1998 ©



Liability – the client or his assignee or supervisor in interest agrees to indemnify and hold harmless Alliance Infinite from and against any claims, demands, lawsuits, or actions for damages, including legal fees to persons and/or property tangible, intangible or otherwise which may be brought against Alliance Infinite incidental to, arising out of or in connection with the work to be done, services to be performed or material to be furnished hereunder except for those claims caused solely and completely by the negligence of Alliance Infinite's directors, officers, employees or sub-contractors.

Under no circumstances whatsoever shall Alliance Infinite be liable for any injury or damage to any person or property occurring because of any defect in all design, materials, machinery, equipment or other items which it is the responsibility of Alliance Infinite to inspect under the terms specified hereunder. Nothing herein contained shall be deemed to relieve any seller, or manufacturer of its warranties, express or implied.

In the event, Alliance Infinite's proven negligent in any respect, the liability of, Alliance Infinite agents, employees, and subcontractors for proprietors' claims shall not exceed the greater of US\$ 1,000 or five (5) times the total compensation paid to Alliance Infinite for the work. The proprietor shall save, defend and hold Alliance Infinite harmless against more than US \$ 1,000 or five (5) times the total compensation paid to Alliance Infinite LLC and Group of companies


Author	Rev.	Date of Release	Document ID.	Page
MR	00	01.01.2024	AI-IC-05	1 of 2

Time Sheet No: 14172 / Job Order No. 10194		Sticker No. 14555		Certificate No.: AI-CERT-FK-641	
SECTION	NEEDED CORRECTIONS (if any) DEFECTS NOTED	DATE	CLEARANCE INITIAL		
Shell plate	Satisfactory				
Dish head	Satisfactory				
Compressor & receiver condition	Satisfactory				
Safety valve	Satisfactory				
Pressure gauges	Satisfactory				
Shutdown pressure switch	Satisfactory				
Motor, pulley, guards	Satisfactory				
Power output voltage, current	Satisfactory				
Oil, filter serviced	Satisfactory				
Emergency stop	Satisfactory				
Nozzles, piping	Satisfactory				
Coupling, External Paint condition	Satisfactory				
Base frame and supports, lugs	Satisfactory				
Marking / Data Plate	Satisfactory				

A. Items found to be rectified at the above-described equipment:
NONE

B. Recommendations / Remarks
The Air Compressor has been inspected as outlined in this report and inspection scope and found satisfactory for operating at 7.0 bar maximum pressure as per standards and codes specified.

PERIODIC THOROUGH EXAMINATION RECORD

DATE	CONDITION FOUND OR LIMIT OF USE	CORRECTIONS NEEDED OR DEFECTS (IF ANY)	CLEARANCE OR EXAMINER	AUTHORIZED SIGNATORY
01/11/2025	SATISFACTORY	NONE	 Fezan Khan	 Sheikh Mohammad Ismail

Note: the item/s mentioned above SHALL be inspected properly by the user prior to each use for any sign of relevant defects.
The validity of this Certificate is 06 months from the Date of Examination.

Issue Date : **01/11/2025**
Due Date of Next Examination : **30/04/2026**
Current Colour Code if applicable : **N.A.**
Equipment used : **UT GAUGE, PNEUMATIC HAND PUMP**


Stamp