



# الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

## INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

### CERTIFICATE OF CALIBRATION

CERTIFICATE NO : UIC/JED/79904

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **SUDHIR EQUIPMENT RENTAL COMPANY.**  
Address JEDDAH - KINGDOM OF SAUDI ARABIA

Description **SAFETY RELIEF VALVE**  
Manufacturer APPOLO VALVES  
Model 19KFEK200A  
Serial No. N/A  
ID No. SAC-825-021  
Location Calibration Lab (Jeddah)

Receipt Date : 30-Apr-26  
Calibration Date : 30-Apr-26  
Calibration Due Date : 29-Oct-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

#### Reference Standard Equipment Used

| Description                        | Certificate No. | Serial No.  | Due Date  |
|------------------------------------|-----------------|-------------|-----------|
| High Pressure Pneumatic Calibrator | SA19-9047-75821 | 214E2408004 | 24-Dec-26 |
| Digital Pressure Gauge             | SA19-9047-75820 | 2232406117  | 24-Dec-26 |

Calibrated By

2  
CALIBRATOR

Calibration Engineer



UIC-QP-7.8-24 F02, REV 0

Approved By

QA/QC Engineer

PAGE : 1 of 2

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.  
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881  
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية  
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤  
هاتف ٠٥١٥ ١٣ ٣٦٧ +٩٦٦



CERTIFICATE NO : UIC/JED/79904

PAGE

2 of 2

|                     |                                         |                             |           |
|---------------------|-----------------------------------------|-----------------------------|-----------|
| <b>Customer</b>     | <b>SUDHIR EQUIPMENT RENTAL COMPANY.</b> |                             |           |
| <b>Address</b>      | JEDDAH - KINGDOM OF SAUDI ARABIA        |                             |           |
| <b>Description</b>  | <b>SAFETY RELIEF VALVE</b>              |                             |           |
| <b>Manufacturer</b> | APPOLO VALVES                           | <b>Calibration Date</b>     | 30-Apr-26 |
| <b>Model</b>        | 19KFEK200A                              | <b>Calibration Due Date</b> | 29-Oct-26 |
| <b>Serial No.</b>   | N/A                                     | <b>Temperature</b>          | 21.6°C    |
| <b>ID No.</b>       | SAC-825-021                             | <b>Relative Humidity</b>    | 47%       |

Test Results

|                                     |          |                                 |
|-------------------------------------|----------|---------------------------------|
| Set Pressure :                      | 10.0 Bar | Spring No./ Press. Range : ---- |
| Back Pressure:                      | 0.0 Bar  | Size Inlet / Outlet : 1" x 1¼"  |
| CDTP :                              | 10.0 Bar | Type of Valve : Metal Seated    |
| Setting Accuracy : ± 3 % of Setting |          | Test Medium : Air/Gas/Water/Oil |
| Pop Test : PASSED                   |          |                                 |

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Safety relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed below for which the company maintains Traceability to the third party.

Condition of Instrument

|                                              |     |
|----------------------------------------------|-----|
| With in the tolerance on receipt( as found ) | No  |
| The instrument was adjusted                  | Yes |
| The instrument was repaired                  | No  |

\*\*\*\*\* End of the Certificate \*\*\*\*\*



Calibrated By: \_\_\_\_\_

Calibration Engineer

UIC-QP-7.8-24 F02, REV 0

Approved by: \_\_\_\_\_

QA/QC Engineer