




مؤسسة جبال هيمالايا للفحص

JABAL HEMALAYA FOR INSPECTIONS



Certificate of Thorough Visual and Functional Examination of Chiller

Certificate No: JHI-6475-26-C16

Date of Inspection: 08-02-2026

Name of the owner company:

SUDHIR EQUIPMENT RENTAL COMPANY

Location:

YANBU-KSA

Equipment Details

AIR HANDING UNIT

Reference Regulations:

Maker & Date of Manufacture:

SASO 2874:2016

YORK & 2015

Sticker No.

Owner ID.

Model No.

Serial No./ Chassis No.

012461

SCH240-006

YVAA0273DGG50BAV

11531C43566003

Rated voltage.

Frequency.

Dimension.

Phase.

400V

60Hz

5.5 x 2.6 x 2.1 m

3

Description of Test: Visual and Functional Test Were Satisfactory.

Date of Last Examination

Date of Next Examination

N/A

07-08-2026

RECOMMENDATION / REMARKS

At the time of inspection, the equipment was found satisfactory.


***Certificate becomes invalid, if any alteration/major repair/modernization made on the Equipment in which case it must be re-examined and re-tested.**

THIS IS TO CERTIFY THAT the Undersigned, a competent representative, did, attend to examine this equipment in accordance to the aforementioned standard to ascertain its safe working load and that the examination indicated that the said equipment has no indigenous injury or sighted deformation and the safe working load of the said equipment as either identified or test proof loaded is shown. The equipment is satisfactory for its intended use within the limits specified and at the time of inspection was found to be satisfactory for further use, provided there is continuous maintenance applied, implementation of our remarks & recommendations and qualified operators employed.

Authorized Name: M.SHEIK ALLAVUDEEN

Surveyor's Name: KHAIF

Authorized Signature: 

Surveyor's Signature: 



This certificate is granted subject to the condition that is understood and agreed that nothing herein contained shall be deemed to relieve any designer, manufacturer, seller, supplier, repairer or operator of any warranty, express or implied, and Jabal Hemalaya For Inspections liability shall be limited to the acts or omissions of its employees, agents and subcontractors. Under no circumstances whatsoever shall Jabal Hemalaya For Inspections nor their Engineer be liable for any injury or damage to any person or occurring by reason of negligent operation or any defect in materials, machinery, equipment or other items other than such defects ascertainable by normally accepted standards and only those items actually inspected by Jabal Hemalaya For Inspections and which are covered only by this certificate. Any person not a party to the contract pursuant to which this document is delivered may not assert claim against Jabal Hemalaya For Inspections for any liability arising out of errors or omissions which may be contained in said document and in connection with any activities for which it may provide. This certificate shall not be reproduced except in full without the approval of Jabal Hemalaya For Inspections.

Disclaimer: This certificate is issued subject to the observation made at the time of inspection. The company (Jabal Hemalaya) will not be held liable for any damage/losses associated to the equipment/material

Address: Est. Jabal Hemalaya for Inspections, Saudi Arabia, Riyadh, Al Malaz Dist. Po. 12831
CR No: 1010927177, Tel: 0112334900, Email: info@jhinspection.com, www.jhinspection.com

Annex to Certificate of Thorough Examination

Certificate No.: JHI-6475-26-C16

Date of Inspection: 08-02-2026

Documentation	A	B	C	REMARKS
Equipment manufacturer's instruction & operational Manual & last test report/certificate/manufacturing details available	✓			
Visual & Functional Test				
Internal visual	✓			
General Surface	✓			
Condenser fans & Coil	✓			
Battery	✓			
Corrosion	✓			
Contol panel	✓			
Support	✓			
Paint / Structure & Surface	✓			
Pipe Connections (Supports)	✓			
Working Environment	✓			
Foundation / Footing & Anchorage	✓			
Valves / Filters	✓			
Attachment	✓			
Area House Keeping	✓			
Power Cable & Wiring Condition	✓			
General Condition	✓			
A – Satisfactory B – Not Satisfactory C – Not Applicable				

COMMENTS

AT THE TIME OF INSPECTION, THE EQUIPMENT WAS FOUND SATISFACTORY.

Surveyor's Name: **KHAIF**



Surveyor's Signature:

[Handwritten Signature]