



REPORT OF INSPECTION

Cert. No.: 2287251	Date of Examination: 08/08/2026	Sticker No.: 01-100983
Equipment Owner	Sudhir Equipment Rental Company	
Place of Inspection	Dammam Yard.	
Equipment Type	Air Compressor.	
Manufacturer Name	Power Link	
Owner ID	SAC-185-458	
Serial No.	A15390/1	
Model	DS185-7	
Rated Power	185 CFM	
Max. Operating Pressure	33 KW	
Rated Speed	-	

At the request of Sudhir Equipment Rental Company, Surveyor to BUREAU VERITAS, acting within the General Conditions of Services of the Society, attended on 08/08/2026 at Dammam Yard. to witness Test and/or to carry out Thorough Examination of the above-mentioned equipment as per EN 1012

Inspection Activities:

Prior to commencing performance test, visual inspection of the equipment was carried out and no visible defects were observed. The equipment was then operated to all the functions to verify the performance of the equipment.

Result of Inspection:

Based on the visual inspection of the Air Compressor. and upon post-performance test & thorough examination, the above mentioned equipment has been found free from damage and/or permanent deformation at the time of inspection & is considered to be safe for further use, subject to continuous maintenance being applied and qualified operator being employed.

Remarks:

- Maintain regular maintenance.
- Maintain regular housekeeping.

Next Inspection Due on or before: 07/02/2027

Issued at Al Khobar on 09/08/2026

Inspected by

Signature:



Name: Mohamed Elsabry
Position: Inspector



Reviewed by
Signature:



Name: Ahmed Elabady
Position: Reviewer

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.


This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.



CHECKLIST OF TEST AND THOROUGH EXAMINATION

Inspection Sticker No.: 01-100983		Date of Examination: 08/08/2026
DESCRIPTION		CONDITION/REMARKS
1.	Physical condition of the compressor tank	Satisfactory
2.	Condition of the motor	Satisfactory
3.	Condition of the piston	Satisfactory
4.	Display panel / pressure gauges	Satisfactory
5.	Safety valve	Satisfactory
6.	Condition of all valves	Satisfactory
7.	Protective covering	Satisfactory
8.	Any unnecessary vibration observed	Satisfactory
9.	Grounding	Satisfactory
10.	Ventilation condition	Satisfactory
11.	Markings & safety signage	Satisfactory
12.	Lifting points (if any)	Satisfactory
13.	Supporting legs / foundation structure	Satisfactory
14.	Name plate	Satisfactory
Remarks: -		

Inspector to Bureau Veritas
Signature:




Name: Mohamed Elsabry
Position: Inspector

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.

This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.

