


☐ Interim
☒ Final

INSPECTION REPORT

NO. R115221109.02

BV Job nr: KHO.INI.19.206.SA.

PROJECT: Third Party Inspection for TOWER LIGHTS	Ref: KHO.INI.19.206.SA.
BV Client: Sudhir Rentals	P/o nr: N/A (client to BV)
Manufacturer: GENERAC	P/o nr: N/A (client to Manufacturer)

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	Owner ID No.:	QTY
VISUAL EXAMINATION AND FUNCTIONAL TEST OF TOWER LIGHTS	PEC00225524	STL - 219	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No

Title	Reference n°	Rev.	Approved by	Date
ORIGINAL DECLARATION OF CONFORMITY	VTev0 K2	-	GENERAC	2021

INSPECTIONS :

Inspection place & Date or Period:Sudhir Rental Warehouse,
DAMMAM YARD

09 , NOV , 2022

Stage of inspection :

- ☐ Before manufacturing
☐ During manufacturing
☒ Final
☐ Packing

Type of inspection:

- ☐ Pre-inspection meeting
☐ Document and QC record review
☒ Visual examination, checks
☐ Witnessing tests
☐ Manufacturing progress status
☐ Vendor assessment
☒ Final inspection
☐ Packing

(for details see continuation sheet)

Stamping:
☒ No ☐  ☐ 
Results of inspection : ☒ Satisfactory ☐ UnsatisfactoryNon Conformities Reports (NCR):

o NCR's issued during reported period : N/A

o List of outstanding NCR's : N/A

Main Conclusions & Remarks: (for details see continuation sheet)Third party visual inspection of 1 unit of TOWER LIGHTS
was carried out and found satisfactory at the time of Inspection.

Valid Sticker Number : 01-34645

Next visit scheduled: 08 , MAY , 2023


☐ Interim
☒ Final

INSPECTION REPORT

NO. R115221109.02

BV Job nr: KHO.INI.19.206.SA.

Description of the inspections carried out:

1. Introduction:

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the General condition which Regulate the intervention of the society IVS-Lifting/B&F Department at the Request of Sudhir Rentals on the purpose of Third Party Inspection .

2. Scope of Inspection :

a. Visual Inspection & Functional Test of TOWER LIGHTS

1- General Data

Equipment Type	Diesel Soundproof TOWER LIGHTS
Manufacturer	GENERAC / 2021
Model	VTevo K2
Serial No.	PEC00225524
Owner ID No	STL - 219
KVA / KW	1280 W

2- Inspection and Test Results

Acceptance criteria	Result	Remarks
1. Document review (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of Unit, wear, damage, loose connection /components, corrosion.	Pass	Found good condition.
3. Electrical,(conduct general inspection of wiring and connection cable termination, corrosion, damage	Pass	Found good condition.

➤ Conclusion:

The TOWER LIGHTS found in good condition at the time of Inspection.

Inspected by:

AHMED TAHER
EQUIPMENT INSPECTOR

Checked by:

OPERATION TEAM LEADER



Issued at Al Khobar office on **10 , NOV, 2022**