



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/20259721

Customer : SUDHIR EQUIPMENT RENTAL COMPANY

Address : Dammam, Kingdom of Saudi Arabia.

Description : MOBILE TOWER LIGHT

Make : VARADA

Model : SG-7.5

Serial No : VEPL/2023-24/040

ID Number : STL - 293

This is to certify that the device detailed hereby have been tested against traceable International Standards for VISUAL INSPECTION & FUNCTIONAL INSPECTION on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 15-Jan-2024

Due Date: 14-Jul-2024

Additional Certification

Sticker Number: 136050

Inspected By:



Industrial Inspector



Approved By:

QA/QC Department

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

Certificate No: UIC/20259721**Engine Specifications:**

Rated Power	:	1600 W	-	Frequency	:	60 Hz
Engine Make	:	Yanmar	-	Engine Model	:	3TNV80-IGE
Engine No.	:	07496	-	Insulation Class	:	H
Lamp Type	:	Metal Halide	-	Engine speed	:	1800rpm
Alter No	:	G23B068352	-	Manufacture Year	:	2023
L x W x H mm	:	2,560 x 1,390 x 2,560				

Lighting:

Voltage	:	230 Volt
Frequency	:	60Hz
Lamp Type	:	4000 W,

Inspection and Test:


Internal Visual Test	:	Satisfactory
General Surface Test	:	Satisfactory
Tower light Shut-Down	:	Satisfactory

Comments & Recommendations:

The Mobile Tower Light was found to be of good working condition and reliable for safe operation.

1. At the time of inspection the Mobile Tower Light was found satisfactory
2. Avoid shock load of the Mobile Tower Light.
3. On the Date of inspection the equipment found to be of Good Construction, of adequate strength, in good working order and free from apparent defects that affect safe operation.
4. Always understand the operating procedure before using Mobile Tower Light
5. Do not exceed the capacity of the Mobile Tower Light
6. Remember - Safety always comes first!

Inspected By:

Industrial Inspector**Approved By:**

QA/QC Department



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

Work Completion Report For On Site Calibration & Inspection

No. 15200

Client Name & Address of the Site Location:

Mr./Mrs: SUDHIR

Designation: CTrans ASIA

Tel. No.: _____

Fax No.: _____

Purchase Order No : _____

Date Of Calibration /Inspection : 15-JAN-24

Calibration /Inspection Validity : ✓ 6M / 1Y

Location : JUBAIL

UIC Cert. No. /Sticker No.	Description			Calibration Status/ (Sticker Issued)		Final Results/Remarks
	Name/Description	Make/Model	SL.No./ID.No.	Yes	No	
136050	Towel light	96L-75	STL-293	☒	☐	pdy
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
		TOTAL	01	☐	☐	

Calibration Engr Sign: MUDASIR Name: MUDASIR

(Client Sign) Saurabh Name: Saurabh

Witnessed & Approved by

Contact No: +966560811585 Site Location: _____