 © 2021 ASHRAE, Inc.

ALOR MALI KALABAHI, Indonesia

WMO: **973200**

Lat: **8.1371S** Lon: **124.5930E** Elev: **12** StdP: **101.18** Time Zone: **8.00 (E08)** Period: **95-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	8	20.5	21.3	17.3	12.4	24.0	18.1	13.1	24.5	9.8	29.2	8.4	29.6	0.2	N/A	0.336	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	11	6.9	33.2	26.5	32.7	26.4	32.3	26.3	27.6	31.5	27.3	31.1	27.1	30.9	3.8	N/A	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	26.6	22.1	30.1	26.2	21.7	29.8	26.0	21.4	29.7	88.0	31.6	86.6	31.4	85.5	31.1	30.9	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	7.7	6.3	5.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(4)
(5)				WB	16.4	28.9	1.6	1.1	15.3	29.7	14.3	30.3	13.4	30.9	12.3	31.6	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	27.5	27.7	27.3	27.6	27.7	27.6	26.7	26.2	25.9	26.7	28.0	29.1	28.8	(6)
(7)			DBStd	1.30	0.89	0.86	0.74	0.73	0.78	1.03	0.96	0.92	1.15	1.02	0.78	1.06	(7)
(8)			HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)			HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)			CDD10.0	6372	550	486	547	532	546	502	501	493	501	559	573	582	(10)
(11)			CDD18.3	3331	292	252	289	282	287	252	242	235	251	301	323	324	(11)
(12)			CDH23.3	37913	3195	2663	3160	3248	3230	2631	2403	2360	2823	3814	4352	4034	(12)
(13)			CDH26.7	14222	1018	808	1074	1249	1233	910	764	744	1040	1641	2039	1702	(13)
(14)	Wind		WSAvg	1.8	2.1	1.7	1.5	1.4	1.6	1.7	1.9	2.0	1.9	1.9	1.7	1.7	(14)
(15)	Precipitation		PrecAvg	1167	285	258	137	85	55	28	10	5	5	20	64	203	(15)
(16)			PrecMax	1707	547	498	347	256	233	144	66	28	40	100	235	355	(16)
(17)			PrecMin	753	90	100	5	5	4	1	0	0	0	0	5	53	(17)
(18)			PrecStd	239	125	104	75	63	57	34	13	8	10	27	51	82	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		32.6	32.2	32.4	32.6	32.5	32.1	31.3	31.1	32.1	33.3	33.9	33.7	(19)
(20)			MCWB		26.9	26.6	26.9	26.3	26.2	25.5	24.5	24.2	25.1	25.8	26.2	27.3	(20)
(21)		2%	DB		31.7	31.4	31.7	32.1	32.0	31.4	30.8	30.6	31.6	32.6	33.2	33.2	(21)
(22)			MCWB		26.8	26.7	26.8	26.3	26.0	25.3	24.4	24.0	24.9	25.8	26.3	27.1	(22)
(23)		5%	DB		31.1	30.9	31.2	31.7	31.6	30.9	30.4	30.2	31.1	32.2	32.8	32.5	(23)
(24)			MCWB		26.7	26.7	26.6	26.2	25.9	25.1	24.2	23.9	24.6	25.7	26.3	26.9	(24)
(25)		10%	DB		30.4	30.2	30.7	31.2	31.1	30.4	29.9	29.8	30.6	31.7	32.4	31.8	(25)
(26)			MCWB		26.5	26.4	26.5	26.1	25.7	24.9	24.1	23.7	24.4	25.5	26.2	26.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		27.7	27.6	27.7	27.7	27.4	26.8	26.2	25.7	26.3	26.9	27.7	28.1	(27)
(28)			MCDB		31.2	30.8	31.0	31.2	30.9	30.2	29.5	29.6	30.5	31.7	31.9	32.6	(28)
(29)		2%	WB		27.2	27.1	27.3	27.1	26.9	26.4	25.6	25.1	25.9	26.5	27.2	27.6	(29)
(30)			MCDB		30.6	30.4	30.7	30.8	30.6	29.9	29.2	29.5	30.4	31.4	31.7	31.9	(30)
(31)		5%	WB		27.0	26.8	27.0	26.7	26.5	26.0	25.1	24.6	25.5	26.2	26.9	27.2	(31)
(32)			MCDB		30.3	30.0	30.5	30.5	30.3	29.7	28.9	29.1	30.1	31.0	31.6	31.4	(32)
(33)		10%	WB		26.6	26.5	26.7	26.5	26.2	25.6	24.7	24.2	25.0	25.9	26.6	27.0	(33)
(34)			MCDB		29.8	29.6	30.0	30.2	29.9	29.3	28.6	28.7	29.6	30.7	31.2	31.1	(34)
(35)	Mean Daily Temperature Range		MDBR		5.4	5.7	6.3	7.2	7.5	7.7	8.1	8.1	8.1	7.5	6.9	6.1	(35)
(36)		5% DB	MCDBR		6.3	6.6	6.8	7.5	7.7	7.9	8.2	8.2	8.0	7.5	7.2	6.8	(36)
(37)			MCWBR		2.8	3.0	3.2	3.0	3.0	3.2	3.5	3.5	3.3	2.9	2.7	2.7	(37)
(38)		5% WB	MCDBR		5.8	6.1	6.3	7.0	7.2	6.9	7.5	7.6	7.4	7.3	6.7	6.4	(38)
(39)			MCWBR		2.8	3.0	3.2	3.1	3.0	3.1	3.5	3.5	3.4	3.1	2.8	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.473	0.476	0.452	0.435	0.442	0.443	0.428	0.436	0.467	0.514	0.512	0.489	(40)
(41)		taud			2.310	2.298	2.366	2.430	2.405	2.377	2.421	2.376	2.276	2.124	2.159	2.251	(41)
(42)		Ebn at Noon			873	868	874	862	826	809	831	848	849	825	832	855	(42)
(43)		Edh at Noon			138	140	129	116	113	113	110	120	139	165	160	146	(43)
(44)	All-Sky Solar Radiation	RadAvg			5.47	5.64	5.87	5.97	5.46	5.18	5.47	6.23	6.79	6.92	6.66	5.66	(44)
(45)		RadStd			0.50	0.55	0.46	0.38	0.32	0.26	0.22	0.14	0.17	0.34	0.37	0.45	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page