

TEL AVIV BEN GURION, Israel

WMO: **401800**

Lat: **32.011N** Lon: **34.887E** Elev: **41** StdP: **100.83** Time Zone: **2.00 (ISR)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	1	6.2	7.7	-4.2	2.7	19.1	-1.5	3.3	19.5	12.4	14.2	10.9	14.4	2.0	120	0.394	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	8	8.0	35.2	20.5	33.5	21.9	32.2	22.8	26.0	31.0	25.2	30.4	24.7	30.0	5.2	300	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	24.2	19.2	29.3	23.7	18.7	28.9	23.0	17.8	28.5	80.5	30.8	77.5	30.4	75.1	30.1	31.1	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	9.5	8.4	7.5	DB	3.8	40.4	1.6	2.0	2.6	41.9	1.7	43.0	0.8	44.2	-0.3	45.6	(4)
(5)				WB	2.2	26.7	1.8	1.5	1.0	27.8	-0.1	28.7	-1.1	29.6	-2.4	30.7	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	21.2	13.5	14.3	16.5	19.6	22.8	25.5	27.5	28.1	26.8	24.0	19.6	15.4	(6)
(7)			DBStd	5.63	2.23	2.54	3.21	3.47	2.83	1.72	1.15	1.06	1.32	2.31	2.79	2.39	(7)
(8)			HDD10.0	4	2	1	0	0	0	0	0	0	0	0	0	1	(8)
(9)			HDD18.3	474	149	116	77	20	1	0	0	0	0	1	16	94	(9)
(10)			CDD10.0	4084	112	122	202	287	398	464	544	560	503	434	289	169	(10)
(11)			CDD18.3	1513	1	4	20	57	140	214	286	302	253	176	56	4	(11)
(12)			CDH23.3	15166	9	43	215	582	1182	2010	3217	3551	2577	1378	363	38	(12)
(13)			CDH26.7	5750	1	10	79	251	459	719	1311	1487	935	409	84	4	(13)
(14)	Wind		WSAvg	3.3	3.3	3.4	3.4	3.4	3.3	3.4	3.5	3.3	3.2	2.9	2.9	3.1	(14)
(15)	Precipitation		PrecAvg	542	146	98	60	19	3	0	0	0	0	24	71	147	(15)
(16)			PrecMax	1199	525	346	173	154	44	4	1	3	7	115	340	464	(16)
(17)			PrecMin	194	3	0	0	0	0	0	0	0	0	0	0	9	(17)
(18)			PrecStd	198	83	65	44	27	8	1	0	0	1	29	74	103	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	28.1	33.2	37.0	38.6	37.1	35.2	35.0	36.0	35.9	31.7	27.0		(19)
(20)			MCWB	14.0	15.1	16.6	18.4	19.3	20.0	23.2	25.1	22.1	19.5	17.5	14.4		(20)
(21)		2%	DB	21.8	24.0	28.8	32.9	34.2	33.1	33.2	33.2	32.9	32.2	29.0	24.0		(21)
(22)			MCWB	13.3	14.0	15.8	17.6	18.7	21.1	23.5	24.6	23.2	20.2	17.1	14.5		(22)
(23)		5%	DB	20.0	21.3	25.2	29.2	31.1	31.2	32.2	32.2	31.3	30.1	27.1	22.0		(23)
(24)			MCWB	12.9	13.4	15.1	16.6	18.5	21.8	23.7	24.4	23.3	20.7	16.8	14.0		(24)
(25)		10%	DB	18.2	19.3	22.2	26.2	28.9	30.1	31.4	31.8	30.7	28.8	25.1	20.2		(25)
(26)			MCWB	12.7	13.1	14.7	16.2	18.8	21.8	23.6	24.2	23.0	20.6	16.7	13.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	17.0	19.0	20.9	22.5	24.7	26.6	27.2	26.2	24.7	21.1	18.1		(27)
(28)			MCDB	20.0	22.2	27.4	30.8	29.6	30.5	31.7	32.2	31.2	29.0	26.2	22.5		(28)
(29)		2%	WB	15.1	15.6	17.3	19.1	21.4	23.9	25.5	26.2	25.1	23.4	19.9	16.6		(29)
(30)			MCDB	19.2	20.9	23.6	27.2	27.9	29.6	30.7	31.2	30.4	28.1	25.0	21.0		(30)
(31)		5%	WB	14.1	14.7	16.4	18.2	20.7	23.3	24.8	25.6	24.3	22.5	19.0	15.5		(31)
(32)			MCDB	18.3	19.4	22.1	25.1	27.0	28.8	30.2	30.7	29.7	27.5	24.2	19.9		(32)
(33)		10%	WB	13.4	13.9	15.5	17.4	19.9	22.6	24.3	24.9	23.7	21.7	18.1	14.7		(33)
(34)			MCDB	17.3	18.3	21.0	23.8	26.0	28.1	29.7	30.1	29.1	27.0	23.1	18.8		(34)
(35)	Mean Daily Temperature Range		MDBR		8.9	9.6	10.1	10.9	10.6	9.2	8.4	8.0	8.4	9.3	10.1	9.3	(35)
(36)		5% DB	MCDBR		12.1	13.6	15.0	16.6	15.6	11.4	9.6	8.6	9.3	11.8	12.7	12.3	(36)
(37)			MCWBR		6.6	6.8	6.6	6.6	6.4	5.1	4.5	3.9	4.5	5.9	6.1	6.4	(37)
(38)		5% WB	MCDBR		9.8	11.1	12.0	12.9	11.6	9.5	8.5	8.3	8.6	9.4	10.3	9.8	(38)
(39)			MCWBR		6.2	6.6	6.2	6.3	5.8	4.6	4.2	4.1	4.6	5.2	6.1	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.390	0.424	0.469	0.504	0.500	0.431	0.444	0.451	0.441	0.454	0.404	0.386	(40)
(41)		taud			2.238	2.125	1.999	1.925	1.970	2.210	2.184	2.168	2.194	2.138	2.250	2.274	(41)
(42)		Ebn at Noon			812	819	810	797	803	857	844	834	826	778	790	794	(42)
(43)		Edh at Noon			114	140	170	191	184	144	147	148	138	136	112	105	(43)
(44)	All-Sky Solar Radiation	RadAvg			2.98	3.82	5.23	6.39	7.41	8.12	7.89	7.21	6.15	4.66	3.47	2.77	(44)
(45)		RadStd			0.18	0.28	0.30	0.28	0.29	0.12	0.09	0.11	0.15	0.19	0.17	0.17	(45)

Note: In rows (19)–(34) the first value is in the Jan column and the last in the Dec column; the Annual column is empty.

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.45	N/A	-2.00	N/A	N/A	N/A	N/A	-60	+142	+105	(46)
(47)	Regional (15 neighbors)	+0.46	N/A	-2.47	N/A	N/A	N/A	N/A	-77	+152	+103	(47)

Nomenclature: See separate page