

ZHITCKOVICHI, Belarus

WMO: **330270**

Lat: **52.2144N** Lon: **27.8667E** Elev: **449** StdP: **14.46** Time Zone: **3.00 (E03)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	1	-3.3	3.3	-8.9	3.5	-1.5	-2.5	4.9	4.2	14.9	35.3	13.7	32.0	2.8	350	0.504	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	7	18.8	86.2	68.2	83.1	66.7	80.0	65.3	70.9	82.3	69.0	79.2	67.2	76.4	5.7	120	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	67.1	101.3	75.4	65.4	95.2	73.3	63.8	90.1	71.7	35.0	82.5	33.3	79.3	31.9	76.7	77.2	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	13.7	12.0	10.7	DB	-11.2	90.3	6.2	3.3	-15.6	92.7	-19.2	94.6	-22.7	96.5	-27.1	98.9	(4)
(5)				WB	-11.5	73.1	6.1	2.5	-15.9	74.9	-19.5	76.3	-22.9	77.7	-27.4	79.5	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	46.2	24.9	27.1	35.2	47.9	57.5	63.1	67.4	64.8	55.3	45.3	36.4	28.2	(6)
(7)			DBStd	16.91	10.55	10.41	8.34	7.75	7.64	6.03	5.58	5.69	6.20	7.49	8.64	10.09	(7)
(8)			HDD50	3321	777	641	461	129	20	0	0	0	22	183	412	676	(8)
(9)			HDD65	7118	1242	1061	923	514	254	109	37	73	295	610	859	1141	(9)
(10)			CDD50	1937	0	0	2	66	252	393	541	460	181	39	3	0	(10)
(11)			CDD65	258	0	0	0	1	21	51	113	68	4	0	0	0	(11)
(12)			CDH74	2481	0	0	0	23	258	489	1058	600	51	2	0	0	(12)
(13)			CDH80	651	0	0	0	4	56	107	318	162	4	0	0	0	(13)
(14)	Wind		WSAvg	4.8	5.3	5.4	5.5	5.0	4.8	4.7	4.2	4.0	4.0	4.4	5.0	5.1	(14)
(15)	Precipitation		PrecAvg	28.5	1.8	1.7	1.8	1.8	2.7	3.1	4.6	2.8	2.3	2.2	2.0	1.9	(15)
(16)			PrecMax	36.6	3.2	3.3	3.3	3.9	6.0	7.5	9.5	5.7	6.1	8.7	3.8	3.4	(16)
(17)			PrecMin	22.5	0.4	0.8	0.4	0.2	0.9	1.1	1.1	0.4	0.1	0.2	0.4	0.6	(17)
(18)			PrecStd	3.6	0.7	0.6	0.8	0.8	1.1	1.5	2.2	1.3	1.4	1.8	0.9	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		45.2	48.9	61.0	77.1	85.6	87.4	91.1	89.9	80.0	71.5	58.2	48.4	(19)
(20)			MCWB		41.9	43.5	49.0	58.5	64.9	67.3	70.5	71.8	63.3	59.7	52.2	46.0	(20)
(21)		2%	DB		41.9	44.3	56.1	70.7	80.9	83.8	87.0	84.3	74.5	64.1	53.8	45.0	(21)
(22)			MCWB		39.3	40.8	45.8	54.9	63.9	66.3	69.0	68.5	61.6	56.4	50.8	43.1	(22)
(23)		5%	DB		39.4	41.5	51.3	66.4	76.3	80.1	83.6	80.1	70.2	60.0	50.2	42.7	(23)
(24)			MCWB		37.5	38.6	43.5	52.6	61.4	64.3	67.7	65.6	59.6	54.4	47.6	41.1	(24)
(25)		10%	DB		36.7	38.8	47.1	62.0	72.1	76.3	80.2	76.7	66.8	56.6	47.5	39.6	(25)
(26)			MCWB		35.4	36.5	41.2	50.4	58.9	63.5	66.5	64.3	58.0	52.3	45.4	38.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		42.9	44.5	50.5	60.5	68.0	70.2	73.7	73.8	64.8	62.1	53.7	46.5	(27)
(28)			MCDB		44.9	48.0	58.4	73.8	81.0	82.0	85.5	85.4	75.2	69.3	56.4	47.7	(28)
(29)		2%	WB		39.8	41.3	46.9	56.7	65.0	68.3	71.4	70.7	62.6	58.0	50.8	43.5	(29)
(30)			MCDB		41.4	43.7	53.5	66.9	76.5	79.4	83.1	82.0	71.4	62.4	53.7	44.8	(30)
(31)		5%	WB		37.6	39.0	44.1	54.2	62.9	66.5	69.5	68.3	61.0	55.0	47.9	41.1	(31)
(32)			MCDB		39.1	41.0	50.2	63.2	74.1	76.2	79.8	77.0	68.2	59.3	49.9	42.5	(32)
(33)		10%	WB		35.4	36.7	41.9	51.9	60.6	64.7	67.7	66.2	59.2	52.4	45.6	38.1	(33)
(34)			MCDB		36.5	38.5	46.6	59.8	69.7	73.2	77.2	73.1	64.7	56.4	47.3	39.4	(34)
(35)	Mean Daily Temperature Range		MDBR		8.0	10.3	13.3	18.6	19.8	18.2	18.8	19.0	17.6	14.0	8.2	7.5	(35)
(36)		5% DB	MCDBR		7.7	11.4	20.7	26.5	26.6	24.8	24.8	24.9	24.1	19.7	12.8	8.7	(36)
(37)			MCWBR		7.0	8.4	12.1	12.7	11.4	9.9	9.7	10.5	12.7	12.1	9.6	7.6	(37)
(38)		5% WB	MCDBR		7.1	10.1	18.2	22.3	23.5	20.4	21.7	21.1	20.3	17.3	11.7	8.5	(38)
(39)			MCWBR		6.8	8.1	11.5	11.5	10.8	9.4	9.6	9.9	11.3	11.4	9.2	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.303	0.337	0.371	0.422	0.410	0.399	0.428	0.429	0.394	0.359	0.342	0.304	(40)
(41)		taud			2.179	2.127	2.184	2.173	2.279	2.333	2.259	2.249	2.300	2.378	2.288	2.232	(41)
(42)		Ebn at Noon			212	238	256	257	267	271	260	252	247	233	198	191	(42)
(43)		Edh at Noon			22	32	37	42	40	38	40	39	33	25	21	18	(43)
(44)	All-Sky Solar Radiation	RadAvg			239	488	905	1323	1684	1818	1727	1501	1020	563	218	156	(44)
(45)		RadStd			39	91	128	142	148	129	147	120	128	98	23	38	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+2.00	+2.41	N/A	N/A	N/A	N/A	(46)
(47)	Regional (8 neighbors)	+1.06	N/A	N/A	N/A	+1.28	+1.40	N/A	-315	+189	N/A	(47)

[Nomenclature: See separate page]