

PINSK, Belarus

WMO: **330190**

Lat: **52.122N** Lon: **26.112E** Elev: **466** StdP: **14.45** Time Zone: **3.00 (E03)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	1	-0.9	5.3	-5.9	4.1	0.3	0.0	5.6	6.0	16.4	37.8	14.5	35.3	3.3	10	0.484	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	7	17.7	86.0	69.1	82.9	68.0	79.9	66.4	71.7	82.7	69.6	80.0	67.8	77.4	4.7	160	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	67.9	104.3	77.6	65.6	96.2	75.2	63.9	90.5	73.3	35.7	82.8	33.9	79.9	32.4	77.3	78.1	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	13.3	11.2	9.6	DB	-7.5	90.0	5.6	2.8	-11.5	92.0	-14.8	93.7	-17.9	95.2	-22.0	97.3	(4)
(5)				WB	-8.0	74.2	5.4	2.5	-11.9	76.0	-15.1	77.5	-18.1	78.9	-22.1	80.7	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	46.9	25.8	28.2	36.1	48.8	57.9	63.3	67.8	65.5	56.2	46.3	37.1	28.9	(6)
(7)			DBStd	16.71	10.40	9.97	8.28	7.92	7.59	6.24	5.88	5.55	6.12	7.45	8.38	9.68	(7)
(8)			HDD50	3149	750	610	434	115	17	0	0	0	15	163	390	655	(8)
(9)			HDD65	6887	1215	1030	897	489	243	107	39	59	271	581	836	1120	(9)
(10)			CDD50	2026	0	0	3	78	263	398	551	481	201	47	4	0	(10)
(11)			CDD65	285	0	0	0	1	23	55	124	76	6	0	0	0	(11)
(12)			CDH74	2439	0	0	0	21	255	474	1051	590	47	1	0	0	(12)
(13)			CDH80	616	0	0	0	3	52	101	304	153	3	0	0	0	(13)
(14)	Wind		WSAvg	4.8	5.2	5.5	5.5	5.1	4.6	4.6	4.2	3.9	4.0	4.5	5.0	5.0	(14)
(15)	Precipitation		PrecAvg	22.6	1.3	1.1	1.2	1.5	2.1	3.0	3.0	2.2	2.1	2.0	1.7	1.5	(15)
(16)			PrecMax	29.1	4.1	3.1	2.9	4.6	4.6	6.8	6.7	5.9	5.4	5.4	4.6	3.1	(16)
(17)			PrecMin	11.9	0.3	0.2	0.0	0.4	0.6	0.9	0.4	0.2	0.4	0.1	0.6	0.2	(17)
(18)			PrecStd	3.2	0.8	0.6	0.7	0.8	0.9	1.4	1.6	1.3	1.1	1.4	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%		DB	46.2	50.4	61.4	77.0	85.3	87.3	90.4	89.2	79.2	70.7	59.1	48.5	(19)
(20)				MCWB	42.5	44.8	49.8	59.6	66.7	69.9	72.1	72.2	65.7	61.4	53.0	46.6	(20)
(21)		2%		DB	42.8	45.6	56.3	70.6	80.6	83.2	86.7	84.3	74.3	64.8	54.1	45.1	(21)
(22)				MCWB	40.1	41.8	46.6	56.7	64.4	68.0	69.7	69.0	63.0	56.8	50.9	42.9	(22)
(23)		5%		DB	40.2	42.6	51.9	66.2	76.3	79.8	83.4	80.1	70.7	60.8	50.7	42.5	(23)
(24)				MCWB	38.1	39.6	44.4	53.8	62.2	65.6	68.8	67.3	60.3	54.9	48.0	40.9	(24)
(25)		10%		DB	37.5	39.8	47.9	62.1	72.2	76.2	80.3	76.6	67.2	57.4	48.0	39.9	(25)
(26)				MCWB	35.8	37.4	42.4	51.8	59.8	64.1	67.5	64.8	58.5	52.6	45.9	38.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%		WB	43.3	45.6	51.1	61.7	68.9	72.0	74.8	75.5	67.8	62.2	54.0	46.9	(27)
(28)				MCDB	45.3	49.5	58.6	75.7	82.6	84.5	85.3	86.1	76.0	69.6	57.3	48.2	(28)
(29)		2%		WB	40.4	42.4	47.7	57.7	65.7	69.3	72.1	71.0	63.7	58.4	51.3	43.3	(29)
(30)				MCDB	42.3	44.9	54.5	68.1	77.1	80.5	83.3	81.4	72.4	63.2	54.2	44.8	(30)
(31)		5%		WB	38.1	40.0	45.1	55.1	63.2	67.3	70.0	68.5	61.5	55.5	48.4	41.0	(31)
(32)				MCDB	39.8	42.3	50.7	64.2	74.1	77.3	80.4	77.6	68.4	59.3	50.5	42.4	(32)
(33)		10%		WB	36.0	37.5	42.9	52.8	61.0	65.1	68.3	66.3	59.5	53.0	46.0	38.6	(33)
(34)				MCDB	37.4	39.7	47.4	60.6	70.5	73.6	78.2	74.3	65.6	57.2	47.8	39.8	(34)
(35)	Mean Daily Temperature Range			MDBR	7.8	9.4	12.6	16.8	18.6	17.5	17.7	17.7	16.1	13.2	8.2	7.5	(35)
(36)		5% DB		MCDBR	8.2	11.4	19.5	23.4	24.8	23.1	22.6	23.2	22.0	18.8	12.6	9.1	(36)
(37)				MCWBR	7.0	8.9	12.0	12.0	11.5	10.8	9.6	11.0	11.9	11.6	9.3	7.9	(37)
(38)		5% WB		MCDBR	7.7	10.9	17.7	20.7	22.1	20.6	20.1	20.9	18.6	16.6	11.4	8.7	(38)
(39)				MCWBR	6.9	9.0	11.4	11.1	11.2	10.6	9.8	11.6	11.6	11.2	9.0	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.304	0.340	0.372	0.423	0.412	0.401	0.431	0.429	0.396	0.359	0.344	0.306	(40)
(41)		taud			2.198	2.154	2.196	2.165	2.264	2.318	2.243	2.243	2.292	2.375	2.289	2.246	(41)
(42)		Ebn at Noon			213	238	256	257	267	271	259	252	246	233	197	192	(42)
(43)		Edh at Noon			22	31	36	43	40	39	41	39	33	25	21	18	(43)
(44)	All-Sky Solar Radiation	RadAvg			242	487	892	1319	1674	1802	1706	1497	1017	565	227	160	(44)
(45)		RadStd			38	83	124	140	156	126	149	118	136	104	21	37	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+2.05	N/A	N/A	N/A	N/A	(46)
(47)	Regional (9 neighbors)	+0.95	N/A	N/A	N/A	+1.06	+1.03	N/A	-284	+171	+68	(47)

Nomenclature: See separate page