CAP DE LA HEVE, France

WMO: **070280**

Lat: **49.5089N** Lon: **0.0711E** Elev: **104** StdP: **100.08** Time Zone: **1.00 (EUC)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	1	-2.7	-1.3	-7.6	2.0	-0.9	-5.6	2.4	0.1	20.7	9.1	18.7	9.1	4.5	60	0.627	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	8	5.7	27.2	19.4	24.8	18.3	22.8	17.4	20.2	25.5	19.1	23.1	18.2	21.6	3.9	110	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	18.3	13.3	21.8	17.5	12.7	20.7	16.8	12.1	19.8	58.2	25.7	54.6	23.2	51.8	21.7	24.5	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	16.9	14.4	12.4	DB	-4.2	31.3	1.8	2.5	-5.5	33.1	-6.5	34.5	-7.5	36.0	-8.8	37.8	(4)
(5)				WB	-5.5	22.0	1.9	1.2	-6.8	22.9	-7.9	23.6	-9.0	24.2	-10.3	25.1	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	11.6	5.6	5.9	7.9	10.1	12.9	15.9	17.9	18.0	16.1	13.1	9.3	6.5	(6)
(7)			DBStd	5.32	3.35	3.05	2.88	3.03	3.06	2.88	2.58	2.62	2.51	2.89	2.78	3.36	(7)
(8)			HDD10.0	534	137	116	76	33	6	0	0	0	1	8	44	114	(8)
(9)			HDD18.3	2519	394	347	322	246	171	86	39	36	76	162	272	368	(9)
(10)			CDD10.0	1132	1	2	12	37	97	176	244	247	183	105	22	4	(10)
(11)			CDD18.3	74	0	0	0	1	3	12	24	24	8	1	0	0	(11)
(12)			CDH23.3	379	0	0	0	1	13	86	124	123	29	2	0	0	(12)
(13)			CDH26.7	91	0	0	0	0	1	21	32	33	5	0	0	0	(13)
(14)	Wind		WSAvg	5.4	6.3	6.0	5.6	5.0	4.9	4.5	4.6	4.6	4.7	5.9	6.2	6.4	(14)
(15)	Precipitation		PrecAvg	852	74	62	53	56	59	63	57	69	70	95	96	100	(15)
(16)			PrecMax	1125	157	120	180	117	106	142	124	176	159	207	221	205	(16)
(17)			PrecMin	532	8	12	10	5	12	9	9	9	15	11	23	22	(17)
(18)			PrecStd	125	36	32	35	32	25	35	29	43	34	48	45	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		12.3	14.7	18.1	22.5	25.2	29.3	30.1	30.3	26.8	22.2	16.5	13.3	(19)
(20)			MCWB		10.5	9.6	12.1	14.7	17.7	20.3	20.3	20.5	18.4	17.0	14.3	11.3	(20)
(21)		2%	DB		11.2	11.9	15.6	19.1	22.5	25.9	26.5	26.7	23.2	19.6	14.7	12.3	(21)
(22)			MCWB		9.9	9.1	10.9	13.2	16.1	19.2	19.3	18.9	17.3	16.1	12.8	10.9	(22)
(23)		5%	DB		10.4	10.7	13.3	16.6	20.1	22.9	24.0	23.9	21.0	17.9	13.8	11.6	(23)
(24)			MCWB		9.2	8.8	9.8	11.7	14.9	17.3	18.2	18.2	16.5	15.3	12.3	10.4	(24)
(25)		10%	DB		9.6	9.7	11.7	14.4	17.9	20.4	21.9	21.6	19.5	16.8	13.0	10.7	(25)
(26)			MCWB		8.5	8.3	9.3	10.8	14.0	16.2	17.4	17.4	16.0	14.7	11.6	9.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		11.1	10.7	12.9	15.6	18.7	21.2	21.7	21.6	19.7	17.7	14.9	12.2	(27)
(28)			MCDB		11.7	12.6	16.8	20.2	24.1	28.0	28.3	27.9	23.9	20.7	16.0	12.8	(28)
(29)		2%	WB		10.2	9.9	11.5	13.5	16.8	19.3	20.1	19.9	18.3	16.6	13.4	11.3	(29)
(30)			MCDB		11.0	11.3	14.2	18.0	21.0	25.2	25.2	24.8	21.4	18.9	14.2	12.1	(30)
(31)		5%	WB		9.5	9.1	10.6	12.3	15.5	17.8	18.9	18.8	17.4	15.7	12.6	10.6	(31)
(32)			MCDB		10.2	10.2	12.5	15.9	19.1	22.2	22.4	22.3	20.0	17.5	13.6	11.4	(32)
(33)		10%	WB		8.7	8.5	9.7	11.2	14.3	16.6	18.0	18.0	16.7	15.0	11.8	9.7	(33)
(34)			MCDB		9.4	9.5	11.3	13.7	17.4	19.6	21.1	20.8	18.9	16.5	12.9	10.6	(34)
(35)	Mean Daily Temperature Range		MDBR		3.5	3.9	4.6	5.5	5.7	6.0	5.8	5.7	5.5	4.8	3.8	3.6	(35)
(36)		5% DB	MCDBR		3.5	5.2	7.4	8.7	9.4	10.7	10.3	9.4	8.1	5.9	4.4	3.7	(36)
(37)			MCWBR		3.3	3.6	4.5	5.0	5.4	5.8	5.0	4.4	4.3	3.9	3.7	3.5	(37)
(38)		5% WB	MCDBR		3.4	4.2	5.9	7.7	8.6	9.4	8.6	7.9	6.5	5.2	4.2	3.6	(38)
(39)			MCWBR		3.5	3.5	4.1	4.7	5.3	5.6	4.7	4.7	4.0	3.9	3.8	3.6	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.326	0.343	0.377	0.395	0.400	0.400	0.394	0.389	0.373	0.358	0.333	0.320	(40)
(41)		taud			2.433	2.410	2.315	2.285	2.314	2.347	2.364	2.399	2.427	2.457	2.453	2.402	(41)
(42)		Ebn at Noon			721	798	826	849	859	861	860	848	824	770	705	668	(42)
(43)		Edh at Noon			64	82	106	121	123	120	116	107	94	78	62	58	(43)
(44)	All-Sky Solar Radiation	RadAvg			0.89	1.62	2.79	4.35	5.12	5.71	5.48	4.60	3.54	2.02	1.07	0.74	(44)
(45)		RadStd			0.09	0.21	0.31	0.43	0.42	0.56	0.38	0.34	0.22	0.18	0.12	0.09	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page