© 2021 ASHRAE, Inc.

YUANMOU, China

WMO: **567630**

Lat: **25.7224N** Lon: **101.8717E** Elev: **1120** StdP: **88.57** Time Zone: **8.00 (E08)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR 99.6%			Humidification DP/MCDB and HR 99%			Coldest Month WS/MCDB 0.4%		Coldest Month WS/MCDB 1%		MCWS/PCWD to 99.6% DB		WSF	
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	12	5.2	6.6	-4.6	2.9	24.0	-3.1	3.3	23.5	7.6	22.4	6.9	22.9	0.5	90	0.298	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB 0.4%		Cooling DB/MCWB 1%		Cooling DB/MCWB 2%		Evaporation WB/MCDB 0.4%		Evaporation WB/MCDB 1%		Evaporation WB/MCDB 2%		MCWS/PCWD to 0.4% DB		
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	6	8.6	36.1	19.4	34.8	19.4	33.7	19.6	23.7	29.0	23.2	28.6	22.9	28.3	3.7	160	(2)

	Dehumidification DP/MCDB and HR 0.4%			Dehumidification DP/MCDB and HR 1%			Dehumidification DP/MCDB and HR 2%			Enthalpy/MCDB 0.4%		Enthalpy/MCDB 1%		Enthalpy/MCDB 2%		Extreme Max WB	
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	22.6	19.8	25.5	22.1	19.2	25.1	21.6	18.7	24.9	78.2	29.1	76.2	28.7	74.5	28.3	29.0	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature Mean		Extreme Annual Temperature Standard Deviation		n-Year Return Period Values of Extreme Temperature n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	7.0	6.1	5.3	DB	2.5	37.9	1.4	1.5	1.5	39.0	0.7	39.9	0.0	40.7	-1.0	41.7	(4)
(5)				WB	1.9	25.1	1.2	0.9	1.0	25.7	0.3	26.3	-0.4	26.8	-1.3	27.4	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	22.4	15.6	18.3	21.6	24.9	26.7	27.1	26.3	26.2	25.0	22.7	18.5	15.4	(6)
(7)			DBStd	5.02	2.47	2.78	2.77	3.06	3.75	3.09	2.26	2.04	2.83	2.71	2.31	2.36	(7)
(8)			HDD10.0	3	1	1	0	0	0	0	0	0	0	0	0	1	(8)
(9)			HDD18.3	254	87	31	8	2	2	0	0	0	1	3	26	95	(9)
(10)			CDD10.0	4523	176	234	359	448	519	513	506	501	451	394	254	167	(10)
(11)			CDD18.3	1733	4	31	108	201	262	263	248	243	202	139	29	3	(11)
(12)			CDH23.3	16924	107	409	1202	2236	3033	2834	2181	2017	1585	949	296	74	(12)
(13)			CDH26.7	6958	6	82	423	1067	1543	1308	841	762	592	288	43	3	(13)
(14)	Wind		WSAvg	2.0	2.2	2.6	2.7	2.7	2.5	2.2	1.6	1.4	1.5	1.7	1.5	1.8	(14)
(15)	Precipitation		PrecAvg	619	4	3	5	13	40	114	141	125	92	57	20	7	(15)
(16)			PrecMax	907	17	13	29	70	121	228	302	312	189	230	93	42	(16)
(17)			PrecMin	287	0	0	0	0	0	14	45	58	30	2	0	0	(17)
(18)			PrecStd	125	5	4	7	17	32	53	59	54	43	45	23	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		27.4	30.8	33.2	36.2	38.2	37.8	35.4	34.9	34.4	32.1	29.6	27.1	(19)
(20)			MCWB		12.7	13.9	15.0	17.0	19.5	21.1	21.9	22.0	21.5	19.8	16.3	13.2	(20)
(21)		2%	DB		25.8	29.0	31.7	34.7	36.3	35.6	33.6	33.3	32.9	30.8	27.9	25.3	(21)
(22)			MCWB		12.0	13.3	14.6	16.4	18.8	21.2	22.3	22.1	21.4	19.2	16.0	13.0	(22)
(23)		5%	DB		24.5	27.5	30.5	33.5	34.9	33.9	32.3	32.0	31.6	29.7	26.5	23.9	(23)
(24)			MCWB		11.8	12.8	14.2	16.2	18.8	21.4	22.3	22.0	21.1	19.0	15.6	12.6	(24)
(25)		10%	DB		23.0	26.1	29.2	32.2	33.5	32.5	31.0	30.7	30.2	28.4	25.1	22.3	(25)
(26)			MCWB		11.3	12.3	13.9	15.9	18.7	21.5	22.3	21.9	20.9	18.7	15.1	12.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		14.2	15.4	16.6	18.8	22.5	24.1	24.5	24.2	23.2	21.6	19.2	15.4	(27)
(28)			MCDB		23.9	27.8	28.5	30.0	29.8	30.0	29.7	29.6	28.5	27.2	24.2	23.0	(28)
(29)		2%	WB		13.2	14.1	15.7	17.9	21.6	23.4	23.8	23.5	22.6	20.9	18.0	14.2	(29)
(30)			MCDB		22.9	26.4	27.8	30.3	29.1	29.4	28.9	28.8	28.3	26.7	23.8	22.2	(30)
(31)		5%	WB		12.5	13.4	15.2	17.3	21.0	22.9	23.3	23.1	22.1	20.4	17.1	13.5	(31)
(32)			MCDB		22.0	25.4	27.2	29.6	28.5	29.0	28.5	28.3	27.9	26.3	23.2	21.4	(32)
(33)		10%	WB		11.9	12.7	14.6	16.8	20.4	22.5	22.9	22.6	21.7	19.9	16.2	12.8	(33)
(34)			MCDB		21.1	24.4	26.6	28.9	28.5	28.9	28.1	27.8	27.4	25.7	22.6	20.6	(34)
(35)	Mean Daily Temperature Range		MDBR		15.1	15.2	14.5	12.8	10.4	8.6	7.8	8.6	8.5	9.8	12.9	14.1	(35)
(36)		5% DB	MCDBR		17.3	17.1	16.4	14.6	12.6	10.6	10.2	10.9	10.6	11.9	15.2	16.4	(36)
(37)			MCWBR		6.2	5.6	4.8	3.7	3.0	2.8	2.7	2.6	2.4	3.0	4.8	5.9	(37)
(38)		5% WB	MCDBR		15.7	15.8	14.0	12.6	9.7	8.6	8.3	8.9	8.8	9.0	12.1	14.3	(38)
(39)			MCWBR		6.2	5.6	4.5	3.6	3.2	3.2	2.9	2.7	2.6	2.7	4.4	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.339	0.357	0.499	0.501	0.457	0.435	0.455	0.496	0.469	0.430	0.377	0.360	(40)
(41)		taud			2.398	2.355	1.922	1.994	2.222	2.337	2.266	2.124	2.185	2.265	2.340	2.347	(41)
(42)		Ebn at Noon			913	920	802	811	844	857	839	805	819	833	862	870	(42)
(43)		Edh at Noon			104	117	190	182	144	128	137	157	145	127	110	106	(43)
(44)	All-Sky Solar Radiation	RadAvg			4.16	5.06	5.47	5.71	5.38	4.76	4.40	4.42	3.92	3.73	4.02	3.67	(44)
(45)		RadStd			0.34	0.48	0.51	0.52	0.65	0.50	0.31	0.38	0.34	0.46	0.46	0.33	(45)

Historical Trends

		DBAvg	Heating 99% DB	Heating 99% DP	Cooling 1% DB	Cooling 1% WB	Cooling 1% DP	Degree-Days HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.46	N/A	N/A	+0.99	-0.19	-0.32	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	+0.39	N/A	N/A	+0.82	N/A	-0.22	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page