 

# TATURA, Australia

WMO: **958360**

Lat: **36.4378S** Lon: **145.2672E** Elev: **114** StdP: **99.96** Time Zone: **10.00 (AUS)** Period: **01-19** WBAN: **99999**

## Annual Heating, Humidification, and Ventilation Design Conditions

| | Coldest Month | Heating DB | | Humidification DP/MCDB and HR | | | | | | Coldest Month WS/MCDB | | | | MCWS/PCWD to 99.6% DB | | WSF | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | 99.6% | | | 99% | | | 0.4% | | 1% | | | | | |
| | | 99.6% | 99% | DP | HR | MCDB | DP | HR | MCDB | WS | MCDB | WS | MCDB | MCWS | PCWD | | |
| | (a) | (b) | (c) | (d) | (e) | (f) | (g) | (h) | (i) | (j) | (k) | (l) | (m) | (n) | (o) | (p) | |
| (1) | **7** | **-0.5** | **0.7** | **-2.0** | **3.2** | **8.9** | **-0.9** | **3.5** | **8.4** | **11.8** | **11.8** | **9.6** | **11.4** | **0.9** | **170** | **0.524** | (1) |

## Annual Cooling, Dehumidification, and Enthalpy Design Conditions

| | Hottest Month | Hottest Month DB Range | Cooling DB/MCWB | | | | | | Evaporation WB/MCDB | | | | | | MCWS/PCWD to 0.4% DB | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | 0.4% | | 1% | | 2% | | 0.4% | | 1% | | 2% | | | | |
| | | | DB | MCWB | DB | MCWB | DB | MCWB | WB | MCDB | WB | MCDB | WB | MCDB | MCWS | PCWD | |
| | (a) | (b) | (c) | (d) | (e) | (f) | (g) | (h) | (i) | (j) | (k) | (l) | (m) | (n) | (o) | (p) | |
| (2) | **1** | **14.9** | **36.5** | **19.2** | **34.0** | **18.5** | **31.9** | **18.1** | **21.5** | **28.7** | **20.5** | **28.3** | **19.7** | **28.0** | **4.7** | **320** | (2) |

| | Dehumidification DP/MCDB and HR | | | | | | | | | Enthalpy/MCDB | | | | | | Extreme Max WB | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | 0.4% | | | 1% | | | 2% | | | 0.4% | | 1% | | 2% | | | |
| | DP | HR | MCDB | DP | HR | MCDB | DP | HR | MCDB | Enth | MCDB | Enth | MCDB | Enth | MCDB | | |
| | (a) | (b) | (c) | (d) | (e) | (f) | (g) | (h) | (i) | (j) | (k) | (l) | (m) | (n) | (o) | (p) | |
| (3) | **19.7** | **14.6** | **23.6** | **18.2** | **13.3** | **23.1** | **17.0** | **12.3** | **22.3** | **63.2** | **28.2** | **59.5** | **27.9** | **56.5** | **28.1** | **25.4** | (3) |

## Extreme Annual Design Conditions

| | Extreme Annual WS | | | | Extreme Annual Temperature | | | | n-Year Return Period Values of Extreme Temperature | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | Mean | | Standard Deviation | | n=5 years | | n=10 years | | n=20 years | | n=50 years | | |
| | 1% | 2.5% | 5% | | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | |
| | (a) | (b) | (c) | | (e) | (f) | (g) | (h) | (i) | (j) | (k) | (l) | (m) | (n) | (o) | (p) | |
| (4) | **11.5** | **9.4** | **8.1** | DB | **-2.6** | **40.8** | **1.1** | **1.9** | **-3.4** | **42.1** | **-4.0** | **43.2** | **-4.6** | **44.3** | **-5.4** | **45.7** | (4) |
| (5) | | | | WB | **-2.9** | **23.5** | **1.2** | **1.3** | **-3.7** | **24.4** | **-4.4** | **25.2** | **-5.1** | **26.0** | **-5.9** | **26.9** | (5) |

## Monthly Climatic Design Conditions

| | | | | Annual | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | (d) | (e) | (f) | (g) | (h) | (i) | (j) | (k) | (l) | (m) | (n) | (o) | (p) | |
| (6) | Temperatures, Degree-Days and Degree-Hours | | DBAvg | **15.0** | **22.5** | **21.8** | **19.4** | **15.4** | **11.4** | **9.0** | **8.4** | **9.0** | **11.2** | **14.4** | **17.9** | **20.2** | (6) |
| (7) | | | DBStd | **5.94** | **4.01** | **3.56** | **3.56** | **3.23** | **2.53** | **2.15** | **2.13** | **2.22** | **2.88** | **3.44** | **3.94** | **3.92** | (7) |
| (8) | | | HDD10.0 | **183** | **0** | **0** | **0** | **2** | **13** | **44** | **58** | **47** | **18** | **2** | **0** | **0** | (8) |
| (9) | | | HDD18.3 | **1661** | **7** | **9** | **28** | **99** | **216** | **281** | **307** | **289** | **216** | **131** | **54** | **23** | (9) |
| (10) | | | CDD10.0 | **2011** | **389** | **329** | **292** | **163** | **56** | **13** | **9** | **16** | **53** | **139** | **238** | **316** | (10) |
| (11) | | | CDD18.3 | **447** | **138** | **105** | **62** | **9** | **0** | **0** | **0** | **0** | **1** | **9** | **42** | **81** | (11) |
| (12) | | | CDH23.3 | **5554** | **1750** | **1151** | **672** | **98** | **1** | **0** | **0** | **0** | **17** | **183** | **604** | **1079** | (12) |
| (13) | | | CDH26.7 | **2488** | **911** | **518** | **256** | **15** | **0** | **0** | **0** | **0** | **3** | **53** | **241** | **491** | (13) |
| (14) | Wind | | WSAvg | **3.8** | **4.6** | **4.3** | **3.9** | **3.1** | **3.1** | **3.1** | **3.3** | **3.5** | **3.8** | **4.1** | **4.3** | **4.5** | (14) |
| (15) | Precipitation | | PrecAvg | **478** | **37** | **23** | **33** | **35** | **51** | **45** | **50** | **49** | **48** | **40** | **32** | **34** | (15) |
| (16) | | | PrecMax | **854** | **147** | **164** | **119** | **116** | **121** | **142** | **106** | **112** | **112** | **150** | **88** | **118** | (16) |
| (17) | | | PrecMin | **180** | **0** | **0** | **0** | **1** | **4** | **3** | **7** | **4** | **10** | **0** | **2** | **0** | (17) |
| (18) | | | PrecStd | **142** | **34** | **36** | **28** | **27** | **32** | **30** | **24** | **25** | **29** | **33** | **24** | **30** | (18) |
| (19) | Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures | 0.4% | DB | **40.7** | **38.5** | **35.4** | **28.6** | **22.1** | **17.2** | **16.5** | **19.6** | **25.4** | **31.5** | **34.9** | **38.2** | | (19) |
| (20) | | | MCWB | **19.7** | **20.6** | **19.0** | **17.0** | **14.0** | **12.5** | **11.8** | **12.8** | **13.7** | **15.9** | **17.6** | **18.5** | | (20) |
| (21) | | 2% | DB | **37.3** | **34.4** | **31.9** | **25.9** | **19.9** | **15.6** | **14.7** | **17.0** | **22.0** | **28.0** | **32.1** | **34.8** | | (21) |
| (22) | | | MCWB | **19.5** | **19.5** | **18.3** | **16.1** | **13.8** | **11.6** | **11.0** | **11.7** | **13.4** | **15.3** | **17.0** | **18.2** | | (22) |
| (23) | | 5% | DB | **34.4** | **32.0** | **29.5** | **24.1** | **18.1** | **14.4** | **13.5** | **15.4** | **19.6** | **25.0** | **29.5** | **31.8** | | (23) |
| (24) | | | MCWB | **18.9** | **19.0** | **17.6** | **15.4** | **13.2** | **11.0** | **10.4** | **10.8** | **12.8** | **14.6** | **16.6** | **17.5** | | (24) |
| (25) | | 10% | DB | **31.7** | **29.8** | **27.1** | **22.2** | **16.6** | **13.4** | **12.5** | **14.0** | **17.6** | **22.5** | **26.9** | **29.2** | | (25) |
| (26) | | | MCWB | **18.5** | **18.1** | **17.0** | **14.9** | **12.5** | **10.6** | **9.8** | **10.3** | **11.9** | **13.8** | **16.2** | **16.9** | | (26) |
| (27) | Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures | 0.4% | WB | **22.9** | **23.5** | **21.1** | **18.5** | **16.2** | **14.0** | **13.1** | **13.7** | **16.4** | **18.3** | **20.7** | **21.9** | | (27) |
| (28) | | | MCDB | **31.8** | **32.0** | **28.2** | **24.4** | **18.3** | **15.2** | **14.9** | **17.4** | **20.4** | **25.3** | **28.4** | **26.6** | | (28) |
| (29) | | 2% | WB | **21.5** | **21.5** | **19.8** | **17.2** | **14.5** | **12.5** | **11.7** | **12.5** | **14.7** | **16.7** | **19.1** | **20.3** | | (29) |
| (30) | | | MCDB | **29.9** | **28.0** | **26.9** | **23.0** | **18.0** | **14.4** | **13.5** | **15.7** | **19.7** | **23.3** | **26.6** | **26.9** | | (30) |
| (31) | | 5% | WB | **20.4** | **20.4** | **18.9** | **16.4** | **13.7** | **11.7** | **11.0** | **11.5** | **13.4** | **15.7** | **18.0** | **19.2** | | (31) |
| (32) | | | MCDB | **29.9** | **27.5** | **26.9** | **22.0** | **17.0** | **13.5** | **12.7** | **14.6** | **18.3** | **22.1** | **25.6** | **27.8** | | (32) |
| (33) | | 10% | WB | **19.5** | **19.4** | **17.9** | **15.5** | **12.9** | **10.9** | **10.2** | **10.6** | **12.3** | **14.7** | **17.0** | **18.2** | | (33) |
| (34) | | | MCDB | **29.3** | **27.3** | **25.6** | **21.0** | **16.2** | **12.8** | **12.1** | **13.5** | **16.8** | **21.5** | **24.3** | **27.4** | | (34) |
| (35) | Mean Daily Temperature Range | | MDBR | **14.9** | **13.8** | **13.2** | **12.7** | **11.0** | **9.2** | **8.5** | **10.1** | **12.0** | **13.7** | **14.1** | **14.6** | | (35) |
| (36) | | 5% DB | MCDBR | **19.1** | **17.2** | **16.5** | **15.1** | **12.8** | **10.8** | **9.6** | **12.5** | **15.3** | **18.2** | **18.1** | **18.6** | | (36) |
| (37) | | | MCWBR | **5.5** | **5.3** | **5.4** | **6.7** | **7.3** | **7.1** | **6.4** | **7.7** | **8.0** | **7.6** | **6.1** | **5.8** | | (37) |
| (38) | | 5% WB | MCDBR | **15.1** | **13.6** | **13.3** | **12.3** | **11.1** | **8.1** | **7.9** | **10.6** | **12.5** | **13.9** | **13.8** | **14.0** | | (38) |
| (39) | | | MCWBR | **5.6** | **5.5** | **5.3** | **5.9** | **6.7** | **5.8** | **5.8** | **7.0** | **7.3** | **7.1** | **5.7** | **5.8** | | (39) |
| (40) | Clear-Sky Solar Irradiance | | taub | | **0.345** | **0.344** | **0.322** | **0.312** | **0.301** | **0.292** | **0.290** | **0.300** | **0.326** | **0.329** | **0.344** | **0.336** | (40) |
| (41) | | | taud | | **2.478** | **2.495** | **2.552** | **2.551** | **2.557** | **2.582** | **2.585** | **2.534** | **2.447** | **2.463** | **2.461** | **2.499** | (41) |
| (42) | | | Ebn at Noon | | **989** | **967** | **952** | **902** | **854** | **836** | **860** | **902** | **930** | **971** | **984** | **1003** | (42) |
| (43) | | | Edh at Noon | | **116** | **109** | **95** | **84** | **73** | **66** | **70** | **84** | **104** | **112** | **117** | **114** | (43) |
| (44) | All-Sky Solar Radiation | | RadAvg | | **7.74** | **6.84** | **5.59** | **3.99** | **2.72** | **2.08** | **2.25** | **3.19** | **4.51** | **5.97** | **6.94** | **7.72** | (44) |
| (45) | | | RadStd | | **0.40** | **0.36** | **0.25** | **0.19** | **0.17** | **0.24** | **0.12** | **0.24** | **0.38** | **0.47** | **0.35** | **0.34** | (45) |

## Historical Trends

| | | DBAvg | Heating | | Cooling | | | Degree-Days | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | 99% DB | 99% DP | 1% DB | 1% WB | 1% DP | HDD10.0 | HDD18.3 | CDD10.0 | CDD18.3 | |
| | | (d) | (e) | (f) | (g) | (h) | (i) | (j) | (k) | (l) | (m) | |
| (46) | Station Only | **+0.49** | **N/A** | **N/A** | **N/A** | **N/A** | **N/A** | **N/A** | **N/A** | **N/A** | **N/A** | (46) |
| (47) | Regional (32 neighbors) | **+0.49** | **N/A** | **N/A** | **+0.92** | **N/A** | **N/A** | **-19** | **-116** | **+174** | **+73** | (47) |

Nomenclature: See separate page